SCS Global Services does hereby certify that an independent assessment has been conducted on behalf of:

PROSOCO, Inc.

3741 Greenway Circle, Lawrence, KS, United States

For the following product(s):

Concrete and Masonry Coatings and Finishes:

Breathable Masonry Coating (BMC[®]) II, Saltguard[®] WB, SingleStep[®] WB, Sure Klean[®] Weather Seal Interior Masonry Dustproofer, Sure Klean[®] Weather Seal Siloxane WB Concentrate, Blok-Guard[®] & Graffiti Control WB 15, Blok-Guard[®] & Graffiti Control WB 6





Indoor Air Quality Certified to SCS-EC10.3-2014 v4.1

Conforms to the CDPH/EHLB Standard Method (CA 01350) v1.2-2017 for the school classroom, private office, and single-family residence parameters when modeled as Flooring. Also conforms to the SCAQMD Rule 1113-Paints & Coatings (June 2011), or CARB SCM 2007, as applicable.

Average Product Application Amount: 1,320 g/m2

Measured Concentration of Total Volatile Organic Compounds (TVOC): Between 0.5- 5.0 mg/m3 (in compliance with CDPH/EHLB Standard Method v1.2-2017)

Methylene Chloride and Perchloroethylene are not intentionally added to certified products.

Registration # SCS-IAQ-05171

Valid from: January 1, 2023 to December 31, 2023







Stanley Wather Kam

Stanley Mathuram, PE, Executive Vice President
SCS Global Services
2000 Powell Street, Ste. 600, Emeryville, CA 94608 USA