SCS Global Services does hereby certify that an independent assessment has been conducted on behalf of:

PROSOCO, Inc.

3741 Greenway Circle, Lawrence, KS, United States

For the following product(s):

Concrete and Masonry Coatings and Finishes:

Blok-Guard® & Graffiti Control WB 6, Blok-Guard® & Graffiti Control WB 15, Breathable Masonry Coating (BMC®) II, Consolideck® First Cut with Densifier, PROSOCO® DensiKure, Saltguard® WB, SingleStep® WB, Sure Klean® Weather Seal Interior Masonry Dustproofer, Sure Klean® Weather Seal Siloxane WB Concentrate

The product(s) meet(s) all of the necessary qualifications to be certified for the following claim(s):



Indoor Air Quality Certified to SCS-EC10.3-2014 v4.1

Conforms to the CDPH/EHLB Standard Method (CA 01350) v1.2-2017 for the school classroom, private office, and single-family residence parameters when modeled as Flooring. Also conforms to the SCAQMD Rule 1113-Paints & Coatings (June 2011), or CARB SCM 2007, as applicable.

Average Product Application Amount: 1,320 g/m²

Measured Concentration of Total Volatile Organic Compounds (TVOC): Between 0.5- 5.0 mg/m³ (in compliance with CDPH/EHLB Standard Method v1.2-2017)

Methylene Chloride and Perchloroethylene are not intentionally added to certified products.

Registration # SCS-IAQ-05171

Valid from: January 1, 2024 to December 31, 2024









Nicole Munoz, Vice President SCS Global Services 2000 Powell Street, Ste. 600, Emeryville, CA 94608 USA