



OVERVIEW OF TESTING CONDUCTED BY PROSOCO, Inc.
FOR OBERFIELDS, INC., DELAWARE, OH

PROJECT No. 0112-08

Three integrally colored split-face CMU's and one smooth-face CMU with large, small and fine aggregate were submitted for testing using PROSOCO's new construction cleaning and water repellent products. **New construction cleaning** was performed using PROSOCO's new construction cleaners to evaluate effective removal of excess mortar and related new construction soiling. **Surface Alterations** were evaluated in conjunction with the cleaning testing to determine the optimal dilutions of PROSOCO's new construction cleaners to provide a uniform appearance using the following criteria: aggregate exposure and surface pigment alteration/removal. **Protective water repellent** testing was performed to evaluate water repellency provided by PROSOCO's water repellents.

The attached report provides information about the PROSOCO products tested and descriptions of the test methods. The report includes test results as well as conclusions and recommendations. Recommendations for cleaning and water repellent treatments for each type concrete masonry unit are also provided in the chart below.

Block	New Construction Cleaning (Type S, 14 day cleaning)	Surface Alterations	Water Repellent
"White" with calcareous aggregate	Sure Klean® Burnished Custom Masonry Cleaner 1:3	Sure Klean® Burnished Custom Masonry Cleaner 1:3	Sure Klean® Custom Masonry Sealer
"Buff" with calcareous aggregate	Sure Klean® Burnished Custom Masonry Cleaner 1:3	Sure Klean® Burnished Custom Masonry Cleaner 1:3	Sure Klean® Custom Masonry Sealer
"Lt. Green" with calcareous aggregate	Sure Klean® Burnished Custom Masonry Cleaner 1:3	Sure Klean® Burnished Custom Masonry Cleaner 1:3	Sure Klean® Custom Masonry Sealer
"Gray" with shale aggregate	Sure Klean® Burnished Custom Masonry Cleaner 1:3	Sure Klean® Burnished Custom Masonry Cleaner 1:3	Sure Klean® Custom Masonry Sealer

Apply all products in accordance with the manufacturer's recommendations provided on container labels and product data sheets. On-site testing should be conducted to determine the most appropriate cleaning or water repellent products and procedures for a particular project. See product literature for additional application and safety information.

PROSOCO
SINCE 1939

Corporate Office

3741 Greenway Circle
Lawrence, KS 66046
(800) 255-4255
(785) 865-4200
fax (785) 830-9016

auto attendant
(800) 491-0721

Customer Care fax
(800) 877-2700

email:
prosoco@prosoco.com

Sales Offices

S. Plainfield, NJ
(908) 754-4410
fax (908) 754-6813

Tucker, GA
(770) 939-9890
fax (770) 621-0716

Carrollton, TX
(972) 939-2608
fax (972) 939-2531

Towson, MD
(410) 321-7597
fax (410) 337-8314

Monroe, NC
(704) 292-1752
fax (704) 292-1652

Cincinnati, OH
(513) 841-2111
fax (513) 841-2333

New Braunfels, TX
(830) 624-1800
fax (830) 624-1801

Burlingame, CA
(650) 579-6669
fax (650) 579-7101