



OVERVIEW OF TESTING CONDUCTED BY PROSOCO, INC.
FOR YAVAPAI BLOCK COMPANY, INC., PRESCOTT, AZ
Project No. 0201-16

Nine types of integrally colored smooth-face and eight types of integrally colored split-face CMUs with large, small and fine aggregate were submitted for testing using PROSOCO's new construction cleaning and water repellent products.

The following recommendations can be made:

New Construction Cleaning: Based on these evaluations, all dilutions tested of Sure Klean® Custom Masonry Cleaner can be recommended on all split-face CMUs and Sure Klean® Burnished Custom Masonry Cleaner can be recommended on all smooth-face CMUs for job-site testing on the submitted CMUs.

Surface Alteration Testing: Based on these evaluations, all dilutions tested of Sure Klean® Custom Masonry Cleaner can be recommended on all split-face CMUs and Sure Klean® Burnished Custom Masonry Cleaner can be recommended on all smooth-face CMUs for job-site testing on the submitted CMUs.

Protective Water Repellents: Based on evaluations the following recommendations are made for job-site testing on the CMUs submitted by Yavapai Block Company, Inc., Prescott, AZ.

PROSOCO
SINCE 1939

Corporate Office
3741 Greenway Circle
Lawrence, KS 66046
(800) 255-4255
(785) 865-4200
fax (785) 830-9016

auto attendant
(800) 491-0721

Customer Care fax
(800) 877-2700

email:
prosoco@prosoco.com

Sales Offices
S. Plainfield, NJ
(908) 754-4410
fax (908) 754-6813

Tucker, GA
(770) 939-9890
fax (770) 621-0716

Carrallton, TX
(972) 939-2608
fax (972) 939-2531

Towson, MD
(410) 321-7597
fax (410) 337-8314

Monroe, NC
(704) 292-1752
fax (704) 292-1652

Cincinnati, OH
(513) 841-2111
fax (513) 841-2333

New Braunfels, TX
(830) 624-1800
fax (830) 624-1801

Burlingame, CA
(650) 579-6669
fax (650) 579-7101

SUBSTRATE	Sure Klean® Custom Masonry Sealer	Sure Klean® Custom Masonry Sealer (2 applications)	Sure Klean® Weather Seal Siloxane WB Concentrate (1:9)	Sure Klean® Weather Seal GP
(A) S+R Grey	Yes	---	Yes	Yes
(B) Med. Wt. Grey	No	No	No	No
(C) SIS Med. Grey	No	Yes	No	No
(D) SIS D/B Grey	No	Yes	Yes	No
(E) Med. Wt. Smooth Brown = Geo Buff/ w/ D/B	No	No	No	No
(F) SIS Med. Wt. Purple Haze	No	No	No	No
(G) Smooth Med. Wt. Sedona Red	No	No	No	No
(H) SIS S+R Purple Haze	No	Yes	No	Yes
(I) Smooth S+R Red	Yes	---	Yes	Yes
(J) SIS S+R AZ. Red	Yes	---	Yes	Yes
(K) SIS Med. Wt. D/B Brown	Yes	---	Yes	Yes
(L) SIS Med. Wt. D/B Golden Rod	No	No	No	No
(M) SIS D/B Sedona Red	No	No	No	No
(N) SIS D/B S+R Sedona Red	No	Yes	No	No
(O) Smooth S+R Purple Haze	Yes	---	Yes	Yes
(P) SIS Med. Wt. Papago Red	No	No	No	No
(Q) Smooth Med. Wt. Brown	No	Yes	No	No



OVERVIEW OF TESTING CONDUCTED BY PROSOCO, INC.
FOR YAVAPAI BLOCK COMPANY, INC., PRESCOTT, AZ
Project No. 0201-16

Apply all products in accordance with the manufacturer's recommendation provided on container labels and product data sheets. On-site testing should be conducted to determine the most appropriate new construction cleaner and water-repellent products and procedures for a particular project. See product literature for additional application and product information.

PROSOCO
SINCE 1939

Corporate Office

3741 Greenway Circle
Lawrence, KS 66046
(800) 255-4255
(785) 865-4200
fax (785) 830-9016

auto attendant
(800) 491-0721

Customer Care fax
(800) 877-2700

email:
prosoco@prosoco.com

Sales Offices

S. Plainfield, NJ
(908) 754-4410
fax (908) 754-6813

Tucker, GA
(770) 939-9890
fax (770) 621-0716

Carrallton, TX
(972) 939-2608
fax (972) 939-2531

Towson, MD
(410) 321-7597
fax (410) 337-8314

Monroe, NC
(704) 292-1752
fax (704) 292-1652

Cincinnati, OH
(513) 841-2111
fax (513) 841-2333

New Braunfels, TX
(830) 624-1800
fax (830) 624-1801

Burlingame, CA
(650) 579-6669
fax (650) 579-7101

www.prosoco.com