## OVERVIEW OF TESTING CONDUCTED BY PROSOCO, Inc. FOR PACIFIC CLAY PRODUCTS, INC., LAKE ELSINORE, CA

(Clay Brick)

## **PROJECTS No. 0210-04**

Fifteen types of clay bricks were submitted for testing using PROSOCO's new construction cleaning and water repellent products. **New construction cleaning** was performed using PROSOCO's new construction cleaners to evaluate effective removal of excess mortar and related new construction soiling. **Surface Alteration** on the clay brick units was evaluated visually based upon perceived discoloration/etching of the submitted samples. **Protective Water Repellent** testing was performed to evaluate water repellency provided by PROSOCO's water repellents. **Graffiti Control** testing was evaluated on the submitted bricks to determine which PROSOCO product(s) are most effective at repelling and facilitating the removal of graffiti; in addition to determining the most effective product to remove graffiti from treated and untreated samples.

The attached report provides information about the PROSOCO products tested and descriptions of the test methods. The report includes test results as well as conclusions and recommendations. Recommendations for cleaning, surface alterations, water repellent, and graffiti control treatments for each type masonry unit are provided in the chart below.

Sample	New Construction Cleaning (Type S mortar, 14 day cleaning)	Limiting Surface Alterations	Water Repellent	Graffiti Control (treatment/remover)
"Sonora" Lt orange/no coating				
"Red FI Vel." Red/no coating				
"Segundo Mod. K" Red/"CEMENT/Lime/ Cblack/UCAR latex/ not fired on"				
"Mesa Tumbled" Red/no coating				Sure Klean <sup>®</sup>
"Napa" Red/no coating				Weather Seal Blok- Guard <sup>®</sup> & Graffiti
"Dark Heritage Red" Dk red/"Sand"				Control
"Frisco Tumbled" Grey/"Englobe"	Sure Klean <sup>®</sup> Vana Trol <sup>®</sup>	Sure Klean <sup>®</sup> Vana Trol <sup>®</sup>	Sure Klean <sup>®</sup> Weather	
"Summer Glacier" Lt yellow/"Englobe"	1:8	1:8	Seal Siloxane PD OR	
"Mt. Whitney" Pale yellow/ "Englobe"	OR Enviro Klean <sup>®</sup> Safety Klean 1:3	OR Enviro Klean <sup>®</sup> Safety Klean 1:3	Sure Klean® Weather Seal Siloxane WB Concentrate (1:9)	
"Merlot Tumbled" Dk purple/"Englobe"				
"Burgundy Sandface" Dk maroon/ "Sand/FeO"				
"Burg. Vel." Maroon/no coating				Defacer Eraser <sup>®</sup> Graffiti Wipe OR
"Santa Rosa" Red/"Englobe/Cblk"				Sure Klean <sup>®</sup> Fast Acting Stripper
"Black Hills Common" Red w/ yellow/ "Englobe"				
"Galena" Red/"Englobe"				

Apply all products in accordance with the manufacturer's recommendations provided on container labels and product data sheets. On-site testing should be conducted to determine the most appropriate cleaning, water repellent, or graffiti control products and procedures for a particular project. See product literature for additional application and safety information.