

OVERVIEW OF TESTING CONDUCTED BY PROSOCO, Inc.
FOR SOUTHERN BRICK & TILE, BYHALIA, MS

PROJECTS No. 0309-10

Ten types of clay bricks were submitted for testing using PROSOCO's new construction cleaning and water repellent products. **New construction cleaning** was performed using PROSOCO's new construction cleaners to evaluate effective removal of excess mortar and related new construction soiling. **Surface Alteration** on the clay brick units was evaluated visually based upon perceived discoloration/etching of the submitted samples. **Protective Water Repellent** testing was performed to evaluate water repellency provided by PROSOCO's water repellents. **Graffiti Control** testing was evaluated on the submitted bricks to determine which PROSOCO product(s) are most effective at repelling and facilitating the removal of graffiti; in addition to determining the most effective product to remove graffiti from treated and untreated samples.

The attached report provides information about the PROSOCO products tested and descriptions of the test methods. The report includes test results as well as conclusions and recommendations. Recommendations for cleaning, surface alterations, water repellent, and graffiti control treatments for each type masonry unit are provided in the chart below.

Sample	New Construction Cleaning (Type N mortar, 21 day cleaning)	Limiting Surface Alterations	Water Repellent	Graffiti Control (treatment/remover)		
"Greenwood Modular"	Sure Klean® Vana Trol® (1:6)	Sure Klean® Vana Trol® (1:6), (1:8)	Sure Klean® Weather Seal Siloxane PD OR Sure Klean® Weather Seal Siloxane WB (1:9)	Sure Klean® Weather Seal Blok-Guard® & Graffiti Control		
"Burgundy Blend Modular"						
"Rosewood Modular"	Sure Klean® Vana Trol® (1:8)					
"Millstone Modular"	Sure Klean® Vana Trol® (1:6), (1:8)					
"Brandywine Modular"	Sure Klean® Vana Trol® (1:6)					
"Byhalia Peach Orchard Modular"	Sure Klean® Vana Trol® (1:6), (1:8)					Defacer Eraser® Graffiti Wipe OR Sure Klean® Fast Acting Stripper
"Early American Modular"						
"Southern Antique"						
"641"						
"641"						

Apply all products in accordance with the manufacturer's recommendations provided on container labels and product data sheets. On-site testing should be conducted to determine the most appropriate cleaning, water repellent, or graffiti control products and procedures for a particular project. See product literature for additional application and safety information.