

**OVERVIEW OF TESTING CONDUCTED BY PROSOCO, Inc.**  
**FOR ADAMS PRODUCTS INC. (WAFFLE HOUSE)**  
**PROJECT No. 0310-03**

One type of integrally colored smooth-face concrete block, with large, small and fine aggregate was submitted for testing using PROSOCO's new construction cleaning and water repellent products. **New construction cleaning** was performed using PROSOCO's new construction cleaners to evaluate effective removal of excess mortar and related new construction soiling. **Color Uniformity** was evaluated in conjunction with the cleaning testing to determine the optimal dilutions of PROSOCO's new construction cleaners to provide a uniform appearance using the following criteria: aggregate exposure and surface pigment alteration/removal. **Protective water repellent** testing was performed to evaluate water repellency provided by PROSOCO's water repellents.

The attached report provides information about the PROSOCO products tested and descriptions of the test methods. The report includes test results as well as conclusions and recommendations. Recommendations for cleaning and water repellent treatments are also provided in the chart below.

<b>Block Type</b>	<b>New Construction Cleaning</b> (Type S mortar, 14 day & Type N mortar, 21 day)	<b>Color Uniformity</b>	<b>Water Repellent</b>
<b>“Superbrick” Smooth-face CMU</b>	Sure Klean® Concrete Brick Cleaner* (1:2) OR (1:3)	Sure Klean® Concrete Brick Cleaner (1:2) OR (1:3)	Sure Klean® Custom Masonry Sealer OR Sure Klean® Weather Seal Blok-Guard® & Graffiti Control

Apply all products in accordance with the manufacturer's recommendations provided on container labels and product data sheets. On-site testing should be conducted to determine the most appropriate cleaning, water repellent, or graffiti control products and procedures for a particular project. See product literature for additional application and safety information.

\*In the original report, this product was called Sure Klean® Burnished Custom Masonry Cleaner. This report was revised when the product name was changed.