

**OVERVIEW OF TESTING CONDUCTED BY PROSOCO, Inc.**  
**FOR STRATA CORPORATION, GRAND FORKS, ND**

**PROJECT No. 0401-03**

Five integrally colored split-face concrete masonry units (CMU's) and five integrally colored smooth-face CMU's all with large, small and fine aggregate and an integral water repellent, Dri-Block<sup>®</sup>, were submitted for testing using PROSOCO's new construction cleaning and water repellent products. **New construction cleaning** was performed using PROSOCO's new construction cleaners to evaluate effective removal of excess mortar and related new construction soiling. **Color Uniformity** was evaluated in conjunction with the cleaning testing to determine the optimal dilutions of PROSOCO's new construction cleaners to provide a uniform appearance using the following criteria: aggregate exposure and surface pigment alteration/removal. **Protective water repellent** testing was performed to evaluate water repellency provided by PROSOCO's water repellents. **Graffiti Control** testing was evaluated to determine which PROSOCO product(s) are most effective at repelling and facilitating the removal of graffiti; in addition to determining the most effective product to remove graffiti from treated and untreated samples.

The attached report provides information about the PROSOCO products tested and descriptions of the test methods. The report includes test results as well as conclusions and recommendations. Recommendations for cleaning, water repellent, and graffiti control treatments for each type masonry unit are also provided in the chart below.

<b>Block</b>	<b>New Construction Cleaning</b> (Type S, 14 day cleaning)	<b>Color Uniformity</b>	<b>Water Repellent</b>	<b>Graffiti Control Treatment/remover</b>
"Natural Gray" split-face	Sure Klean <sup>®</sup> Custom Masonry Cleaner (1:6)	Sure Klean <sup>®</sup> Custom Masonry Cleaner (1:6)	Sure Klean <sup>®</sup> Custom Masonry Sealer	Sure Klean <sup>®</sup> Custom Masonry Sealer
"Natural Gray" smooth-face				
"#470 Charcoal Gray" split-face				
#470 Charcoal Gray" smooth-face				
"257 Medium Brown" split-face				Sure Klean <sup>®</sup> Fast Acting Stripper OR Defacer Eraser <sup>®</sup> Graffiti Wipe
"257 Medium Brown" smooth-face				
"370 Tan" split-face				
"370 Tan" smooth-face				

Block	New Construction Cleaning (Type S, 14 day cleaning)	Color Uniformity	Water Repellent	Graffiti Control Treatment/remover
"154 Red" split-face	Sure Klean® Custom Masonry Cleaner (1:6)	Sure Klean® Custom Masonry Cleaner (1:6)	Sure Klean® Custom Masonry Sealer	Sure Klean® Custom Masonry Sealer
"154 Red" smooth- face				Sure Klean® Fast Acting Stripper <b>OR</b> Defacer Eraser® Graffiti Wipe

Apply all products in accordance with the manufacturer's recommendations provided on container labels and product data sheets. On-site testing should be conducted to determine the most appropriate cleaning, water repellent, or graffiti control products and procedures for a particular project. See product literature for additional application and safety information.