

**OVERVIEW OF TESTING CONDUCTED BY PROSOCO, Inc.**  
**FOR RAGLAND CLAY PRODUCTS, LLC, RAGLAND, AL**

**PROJECT No. 0410-11**

Five types of clay brick were submitted for testing using PROSOCO's new construction cleaning, limiting surface alterations, water repellent products, and graffiti control products. **New construction cleaning** was performed to evaluate effective removal of excess mortar, and related new construction soiling. Products were evaluated to determine if they created any **Surface Alterations** when used on the surface. **Protective Water Repellent** testing was performed to evaluate water repellency provided by PROSOCO's water repellents. **Graffiti Control** testing was evaluated to determine which PROSOCO product(s) are most effective at repelling and facilitating the removal of graffiti; in addition to determining the most effective product to remove graffiti from treated and untreated samples.

The attached report provides information about the PROSOCO products tested and descriptions of the test methods. The report includes test results as well as conclusions and recommendations. Recommendations for new construction cleaning, surface alterations, water repellent, and graffiti control treatments for each type of brick are also provided in the chart below.

**RECOMMENDATIONS**

Sample	New Construction Cleaning (Type N mortar, 21 days)	Limiting Surface Alterations	Water Repellents	Graffiti Repellents	Graffiti Removers
"Full Range Ragtex" "Red Select"	Sure Klean® 600 Detergent (1:8) OR Enviro Klean® Safety Klean (1:3)	Sure Klean® 600 Detergent (1:8) OR Enviro Klean® Safety Klean (1:3)	Sure Klean® Weather Seal Siloxane WB Concentrate 1:9, 1:14 OR Sure Klean® Weather Seal Siloxane PD OR Sure Klean® Weather Seal Blok-Guard® & Graffiti Control	Sure Klean® Weather Seal Blok-Guard® & Graffiti Control	Sure Klean® Fast Acting Stripper OR Defacer Eraser® Graffiti Wipe
"Montrose" "Orleans Blend"	Sure Klean® Vana Troi® (1:8) OR Enviro Klean® Safety Klean (1:3)	Sure Klean® Vana Troi® (1:8) OR Enviro Klean® Safety Klean (1:3)			
"Sandestin"	Enviro Klean® Safety Klean (1:3)	Enviro Klean® Safety Klean (1:3)			

Apply all products in accordance with the manufacturer's recommendations provided on container labels and product data sheets. On-site testing should be conducted to determine the most appropriate products and procedures for a particular project. See product literature for additional application and safety information.