

OVERVIEW OF TESTING CONDUCTED BY PROSOCO, Inc.
FOR GLACIER STONE SUPPLY, LLC, KALISPELL, MT
PROJECT No. 0412-10

Fourteen pieces of “Wolfcreek Flagstone” were submitted for testing to PROSOCO Inc.’s Testing Laboratory with a request to determine if application of the products evaluated will produce any surface alteration during new construction cleaning operations. Additionally, the effectiveness of water repellents, stain repellents and color enhancing treatments suitable for natural stone were evaluated. **New construction cleaning** was performed to evaluate effective removal of excess mortar, and related new construction soiling. Products were evaluated to determine if they created any **Surface Alterations** when used on the surface. **Protective Water Repellent** testing was performed to evaluate water repellency provided by PROSOCO’s water repellents. **Stain Repellent** testing was conducted to determine which PROSOCO product(s) are most effective at repelling and facilitating the removal of stains. **Color Enhancement** was evaluated for its ability to provide color enhancement to the submitted samples.

The attached report provides information about the PROSOCO products tested and descriptions of the test methods. The report includes test results as well as conclusions and recommendations. Recommendations are also provided in the chart below.

RECOMMENDATIONS

Sample	New Construction Cleaning Type N, 21 days)	Limiting Surface Alterations	Water Repellents	Stain Repellent / Maintenance	Color Enhancement
“Wolfcreek Flagstone”	Sure Klean® Vana Trol® (1:8) OR Enviro Klean® Safety Klean (1:3)	Sure Klean® Vana Trol® (1:8) OR Enviro Klean® Safety Klean (1:3)	Sure Klean® Paver Enhancer OR Sure Klean® Weather Seal Natural Stone Treatment OR Sure Klean® Weather Seal SL100 Water Repellent OR Sure Klean® Weather Seal Siloxane WB Concentrate (1:9) OR Stand Off® SLX100 Water & Oil Repellent OR Stand Off® Impregnator	Repellent Stand Off® Stone, Tile & Masonry Protector (STMP) OR Stand Off® SLX 100 Water & Oil Repellent OR Stand Off® Impregnator Maintenance Cleaner Enviro Klean® 2010 All Surface Cleaner (1:10)	Stand Off® Gloss ‘N Guard OR Stand Off® Gloss ‘N Guard WB

Apply all products in accordance with the manufacturer’s recommendations provided on container labels and product data sheets. On-site testing should be conducted to determine the most appropriate cleaning, water repellent, or stain repellent products and procedures for a particular project. See product literature for additional application and safety information.