



**AMT Laboratories**  
 3741 Greenway Circle  
 Lawrence, KS 66046  
 Phone: 888.376.3600  
 Fax: 785.830.9176

***Trenwyth Industries, Emigsville, PA***  
*Project No. 0603-11 PTP*

Eight types of integrally colored ground-face CMU's treated with Dry-Block<sup>®</sup>, all with large, small and fine aggregate were submitted for testing to AMT Laboratories by PROSOCO, Inc. to determine the optimum cleaning/cure time combination for complete removal of mortar and related new construction soiling.

**New Construction Cleaning** was performed to evaluate the effectiveness of the selected PROSOCO products at removing excess Type S mortar, and related new construction soiling, while providing the best color uniformity when compared to the untreated surfaces of the submitted samples.

The attached report provides information about the PROSOCO products tested and descriptions of the test methods. The report includes test results as well as conclusions and recommendations. Recommendations are also provided in the chart below.

**Recommendations**

| Sample                          | New Construction Cleaning<br>Type S Mortar, (14 Day Cleaning)              |
|---------------------------------|--|
| All Submitted Ground-face CMU's | Sure Klean <sup>®</sup> Burnished Custom Masonry Cleaner<br>(1:2) OR (1:3) |

Apply all products in accordance with the manufacturer's recommendations provided on container labels and product data sheets. On-site testing should be conducted to determine the most appropriate cleaning, water repellent, or stain repellent products and procedures for a particular project. See product literature for additional application and safety information.