

AMT Laboratories 3741 Greenway Circle Lawrence, KS 66046 Phone: 888.376.3600 Fax: 785.830.9176

Buchheit Supply, Inc.

Project No. 0604-13 PTP

One type of limestone and one type of sandstone were submitted to AMT Laboratories by PROSOCO, Inc. with a request to determine if application of the products evaluated will produce any surface alterations during new construction cleaning operations. Additionally, the effectiveness of water repellents, graffiti control products and stain repellents suitable for limestone and sandstone were evaluated

New Construction Cleaning was performed to evaluate the effectiveness of the selected PROSOCO products at removing excess Type S Mortar, and related new construction soiling, while limiting potential surface alterations to the decorative finish. **Protective Water Repellent** testing was performed to evaluate which PROSOCO water repellent(s) are most effective at providing protection from wind driven rain. **Graffiti Control** products were evaluated for its ability to repel and remove graffiti from the submitted samples. **Stain Repellency** testing was conducted to determine which PROSOCO product(s) are most effective at repelling and facilitating the removal of stains.

The attached report provides information about the PROSOCO products tested and descriptions of the test methods. The report includes test results as well as conclusions and recommendations. Recommendations are also provided in the chart below.

Recommendations

Sample	New Construction Cleaning Type S Mortar (14 Day Cleaning)	Protective Water Repellents	Graffiti Control	Stain Repellency
"Indiana Limestone"	Sure Klean [®] Vana Trol [®] (1:8)	*Sure Klean [®] Weather Seal Natural Stone Treatment OR *Stand Off [®] Limestone & Marble Protector OR *Sure Klean [®] Weather Seal Blok- Guard [®] & Graffiti Control	<u>Graffiti Repellents</u> *Sure Klean [®] Weather Seal Blok-Guard [®] & Graffiti Control <u>Graffiti Removal</u> Sure Klean [®] Fast Acting Stripper OR Defacer Eraser [®] Graffiti Wipe	Stain Repellent *Stand Off [®] Limestone & Marble Protector OR Stand Off [®] Stone, Tile & Masonry Protector (STMP) Maintenance Cleaner Enviro Klean [®] 2010 All Surface Cleaner (1:10)
"Savannah" Sandstone	Sure Klean [®] Vana Trol [®] (1:8)	*Sure Klean [®] Weather Seal Natural Stone Treatment OR *Stand Off [®] Limestone & Marble Protector OR *Sure Klean [®] Weather Seal Blok- Guard [®] & Graffiti Control	<u>Graffiti Repellents</u> *Sure Klean [®] Weather Seal Blok-Guard [®] & Graffiti Control <u>Graffiti Removal</u> Sure Klean [®] Fast Acting Stripper OR Defacer Eraser [®] Graffiti Wipe	<u>Stain Repellent</u> *Stand Off [®] Limestone & Marble Protector OR Stand Off [®] Stone, Tile & Masonry Protector (STMP) <u>Maintenance Cleaner</u> Enviro Klean [®] 2010 All Surface Cleaner (1:10)

Apply all products in accordance with the manufacturer's recommendations provided on container labels and product data sheets. On-site testing should be conducted to determine the most appropriate cleaning, water repellent, or stain repellent products and procedures for a particular project. See product literature for additional application and safety information.

Document in 0604-13 PTP Buchheit Supply Executive Summary