



AMT Laboratories
 3741 Greenway Circle
 Lawrence, KS 66046
 Phone: 888.376.3600
 Fax: 785.830.9176

Trenwyth Industries, Inc.
Project No. 0608-19 PTP

One type of “Astra-Glaze-SW+[®]” glazed CMU was submitted for testing to AMT Laboratories by PROSOCO, Inc. to determine if the selected cleaners produce any surface alterations to the glazed surface of the submitted sample during new construction cleaning operations. In addition, graffiti control products suitable for glazed CMU’s were evaluated. **Limiting Surface Alterations** was evaluated to determine if surface alterations are created during new construction cleaning. **Graffiti Removal** products were evaluated for its ability to remove graffiti from the submitted samples.

Recommendations

Sample	New Construction Cleaning Type S Mortar (14 Day Cleaning)	Graffiti Control
“Sedona Clay – Astra-Glaze-SW+ [®] ”	Sure Klean [®] Burnished Custom Masonry Cleaner (1:2) OR (1:3) OR Enviro Klean [®] Safety Klean (1:2) OR (1:3)	Graffiti Removal Defacer Eraser [®] Graffiti Wipe

Apply all products in accordance with the manufacturer’s recommendations provided on container labels and product data sheets. On-site testing should be conducted to determine the most appropriate cleaning, water repellent, or stain repellent products and procedures for a particular project. See product literature for additional application and safety information.