



**AMT Laboratories**  
 3741 Greenway Circle  
 Lawrence, KS 66046  
 Phone: 888.376.3600  
 Fax: 785.830.9176

***Oberfield's Inc.***  
*Project No. 0610-13 PTP CMU*

Two types of integrally colored CMUs, all with large, small and fine aggregate were submitted for testing to AMT Laboratories by PROSOCO, Inc. to determine the optimum cleaning/cure time combination for complete removal of mortar and related new construction soiling. The effectiveness of protective water repellents and graffiti control products suitable for CMUs was also evaluated. **New Construction Cleaning** was performed to evaluate the effectiveness of the selected PROSOCO products at removing excess Type N Mortar, and related new construction soiling, while limiting potential surface alterations to the finish. **Protective Water Repellent** testing was performed to evaluate which PROSOCO water repellent(s) are most effective at providing protection from wind driven rain. **Graffiti Control** products were evaluated for its ability to repel and remove graffiti from the submitted samples.

The attached report provides information about the PROSOCO products tested and descriptions of the test methods. The report includes test results as well as conclusions and recommendations. Recommendations are also provided in the chart below.

**Recommendations**

Sample	New Construction Cleaning Type S Mortar (14 Day Cleaning)	Protective Water Repellents	Graffiti Control
<p style="text-align: center;"><b>“Smokey Rose #262 Smooth”</b></p>	<p style="text-align: center;">Sure Klean® Burnished Custom Masonry Cleaner (1:2) OR (1:3)</p>	<p style="text-align: center;">*Sure Klean® Custom Masonry Sealer OR Sure Klean® Weather Seal Blok-Guard® &amp; Graffiti Control II</p>	<p style="text-align: center;"><b><u>Graffiti Repellents</u></b> *Sure Klean® Custom Masonry Sealer OR Sure Klean® Weather Seal Blok-Guard® &amp; Graffiti Control II</p> <p style="text-align: center;"><b><u>Graffiti Removers</u></b> Defacer Eraser® Graffiti Wipe OR Sure Klean® Fast Acting Stripper</p>
<p style="text-align: center;"><b>“Walnut Brown #404 Stri-Face”</b></p>	<p style="text-align: center;">Sure Klean® Custom Masonry Cleaner (1:4) OR (1:6) OR Sure Klean® Burnished Custom Masonry Cleaner (1:2) OR (1:3)</p>	<p style="text-align: center;">*Sure Klean® Custom Masonry Sealer OR Sure Klean® Weather Seal Blok-Guard® &amp; Graffiti Control II</p>	<p style="text-align: center;"><b><u>Graffiti Repellents</u></b> *Sure Klean® Custom Masonry Sealer OR Sure Klean® Weather Seal Blok-Guard® &amp; Graffiti Control II</p> <p style="text-align: center;"><b><u>Graffiti Removers</u></b> Defacer Eraser® Graffiti Wipe OR Sure Klean® Fast Acting Stripper</p>

Apply all products in accordance with the manufacturer’s recommendations provided on container labels and product data sheets. On-site testing should be conducted to determine the most appropriate cleaning, water repellent, or stain repellent products and procedures for a particular project. See product literature for additional application and safety information.

**\*NOTE:** Sure Klean® Custom Masonry Sealer is manufactured and marketed in compliance with USEPA AIM VOC regulations (40 CFR 59.403). This product may not be suitable for sale in states and districts with more restrictive AIM VOC regulations.



**AMT Laboratories**  
 3741 Greenway Circle  
 Lawrence, KS 66046  
 Phone: 888.376.3600  
 Fax: 785.830.9176

***Oberfield's Inc.***  
*Project No. 0610-13 PTP Concrete Paver*

One type of concrete paver was submitted to AMT Laboratories by PROSOCO, Inc. with a request to determine the optimal concentration of cleaner for removal of laboratory applied mortar while leaving the external surface looking most like the natural through-body color of the concrete paver during new construction operations. Additionally, the effectiveness of water repellents, stain repellents and color and sheen enhancement products suitable for concrete pavers was evaluated. **New Construction Cleaning** was performed to evaluate the effectiveness of the selected PROSOCO products at removing excess Type N Mortar, and related new construction soiling, while limiting potential surface alterations to the finish. **Protective Water Repellent** testing was performed to evaluate which PROSOCO water repellent(s) are most effective at providing protection from wind driven rain. **Stain Repellency** testing was conducted to determine which PROSOCO product(s) are most effective at repelling and facilitating the removal of stains. **Color and Sheen Enhancement** was evaluated to determine which PROSOCO product(s) are most effective at providing color and/or sheen enhancement to the submitted samples.

The attached report provides information about the PROSOCO products tested and descriptions of the test methods. The report includes test results as well as conclusions and recommendations. Recommendations are also provided in the chart below.

**Recommendations**

Sample	New Construction Cleaning Type S Mortar (14 Day Cleaning)	Protective Water Repellents	Stain Repellency	Color and Sheen Enhancement
“Autumn Blend” Concrete Paver	Paver Kare® Cleaner/Brightener (1:2) OR (1:3)	Consolideck® Saltguard® WB	<p style="text-align: center;"><b><u>Stain Repellent</u></b></p> Stand Off® SLX100 Water & Oil Repellent OR Stand Off® Stone, Tile & Masonry Protector (STMP)	<p style="text-align: center;"><b><u>Color Enhancement</u></b></p> *Paver Kare® Paver Enhancer OR *Paver Kare® Deep Sheen
			<p style="text-align: center;"><b><u>Maintenance Cleaner</u></b></p> Enviro Klean® 2010 All Surface Cleaner (1:10)	<p style="text-align: center;"><b><u>Sheen Enhancement</u></b></p> Paver Kare® Deep Sheen

Apply all products in accordance with the manufacturer’s recommendations provided on container labels and product data sheets. On-site testing should be conducted to determine the most appropriate cleaning, water repellent, or stain repellent products and procedures for a particular project. See product literature for additional application and safety information.

**\*NOTE:** Paver Kare® Paver Enhancer and Paver Kare® Deep Sheen® are manufactured and marketed in compliance with USEPA AIM VOC regulations (40 CFR 59.403). These products may not be suitable for sale in states and districts with more restrictive AIM VOC regulations.



**AMT Laboratories**  
 3741 Greenway Circle  
 Lawrence, KS 66046  
 Phone: 888.376.3600  
 Fax: 785.830.9176

***Oberfield's Inc.***  
*Project No. 0610-13 PTP Concrete Brick*

Four types of concrete brick, all with large, small and fine aggregate were submitted for testing to AMT Laboratories by PROSOCO, Inc. to determine the optimal concentration of cleaner for complete removal of mortar and related new construction soiling which also leaves the external surface looking most like the uncleaned surface of the concrete brick. The effectiveness of protective water repellents and graffiti control products suitable for concrete brick was also evaluated. **New Construction Cleaning** was performed to evaluate the effectiveness of the selected PROSOCO products at removing excess Type N Mortar, and related new construction soiling, while limiting potential surface alterations to the finish. **Protective Water Repellent** testing was performed to evaluate which PROSOCO water repellent(s) are most effective at providing protection from wind driven rain. **Graffiti Control** products were evaluated for its ability to repel and remove graffiti from the submitted samples.

The attached report provides information about the PROSOCO products tested and descriptions of the test methods. The report includes test results as well as conclusions and recommendations. Recommendations are also provided in the chart below.

**Recommendations**

Sample	New Construction Cleaning Type S Mortar (14 Day Cleaning)	Protective Water Repellents	Graffiti Control
<b>“Steelyard Blend #4” Concrete Brick</b>	Sure Klean® Concrete Brick Cleaner (1:2) OR (1:3)	*Sure Klean® Custom Masonry Sealer OR Sure Klean® Weather Seal Blok-Guard® & Graffiti Control II	<b><u>Graffiti Repellents</u></b> *Sure Klean® Custom Masonry Sealer OR Sure Klean® Weather Seal Blok-Guard® & Graffiti Control II  <b><u>Graffiti Removers</u></b> Defacer Eraser® Graffiti Wipe OR Sure Klean® Fast Acting Stripper
<b>“Steelyard Blend #8” Concrete Brick</b>	Sure Klean® Concrete Brick Cleaner (1:2) OR (1:3)	*Sure Klean® Custom Masonry Sealer OR Sure Klean® Weather Seal Blok-Guard® & Graffiti Control II	<b><u>Graffiti Repellents</u></b> *Sure Klean® Custom Masonry Sealer OR Sure Klean® Weather Seal Blok-Guard® & Graffiti Control II  <b><u>Graffiti Removers</u></b> Defacer Eraser® Graffiti Wipe OR Sure Klean® Fast Acting Stripper
<b>“Steelyard Blend #11” Concrete Brick</b>	Sure Klean® Concrete Brick Cleaner (1:2) OR (1:3)	*Sure Klean® Custom Masonry Sealer OR Sure Klean® Weather Seal Blok-Guard® & Graffiti Control II	<b><u>Graffiti Repellents</u></b> *Sure Klean® Custom Masonry Sealer OR Sure Klean® Weather Seal Blok-Guard® & Graffiti Control II  <b><u>Graffiti Removers</u></b> Defacer Eraser® Graffiti Wipe OR Sure Klean® Fast Acting Stripper

Sample	New Construction Cleaning Type S Mortar (14 Day Cleaning)	Protective Water Repellents	Graffiti Control
<b>“Walnut Brown #404 Stri-Face” “Antique Blend” Limestone Modular Brick</b>	Sure Klean® Concrete Brick Cleaner (1:2) OR (1:3)	*Sure Klean® Custom Masonry Sealer OR Sure Klean® Weather Seal Blok-Guard® & Graffiti Control II	<p style="text-align: center;"><b><u>Graffiti Repellents</u></b></p> <p style="text-align: center;">*Sure Klean® Custom Masonry Sealer OR Sure Klean® Weather Seal Blok-Guard® &amp; Graffiti Control II</p> <p style="text-align: center;"><b><u>Graffiti Removers</u></b></p> <p style="text-align: center;">Defacer Eraser® Graffiti Wipe OR Sure Klean® Fast Acting Stripper</p>

Apply all products in accordance with the manufacturer’s recommendations provided on container labels and product data sheets. On-site testing should be conducted to determine the most appropriate cleaning, water repellent, or stain repellent products and procedures for a particular project. See product literature for additional application and safety information.

**NOTE:** Sure Klean® Custom Masonry Cleaner can be used on integrally colored concrete brick. Use Sure Klean® Concrete Brick Cleaner for concrete brick with surface applied (flash-spray) color.

**\*NOTE:** Sure Klean® Custom Masonry Sealer is manufactured and marketed in compliance with USEPA AIM VOC regulations (40 CFR 59.403). This product may not be suitable for sale in states and districts with more restrictive AIM VOC regulations.