



AMT Laboratories
 3741 Greenway Circle
 Lawrence, KS 66046
 Phone: 888.376.3600
 Fax: 785.830.9176

Anchor Block Company
Project No. 0708-19 PTP

Two types of integrally colored Bravissi™ Sculpted Masonry Veneer, both with large, small and fine aggregate were submitted for testing to AMT Laboratories by PROSOCO, Inc. to determine the optimum concentration of cleaner for complete removal of mortar and related new construction soiling. The effectiveness of protective water repellents, graffiti control products, and a color/sheen enhancement products suitable for Sculpted Masonry Veneer was also evaluated. **New Construction Cleaning** was performed to evaluate the effectiveness of the selected PROSOCO products at removing excess mortar, and related new construction soiling, while limiting potential surface alterations to the finish. **Protective Water Repellent** testing was performed to evaluate which PROSOCO water repellent(s) are most effective at providing protection from wind driven rain. **Graffiti Control** products were evaluated for its ability to repel and remove graffiti from the submitted samples. **Color and Sheen Enhancement** was evaluated to determine which PROSOCO product(s) are most effective at providing color and/or sheen enhancement to the submitted samples. The attached report provides information about the PROSOCO products tested and descriptions of the test methods. The report includes test results as well as conclusions and recommendations. Recommendations are also provided in the chart below. **Recommendations**

Sample	New Construction Cleaning Type S Mortar (14 Day Cleaning) and Type N Mortar (21 Day Cleaning)	Protective Water Repellents	Graffiti Control	Color and Sheen Enhancement
“Endion Red” Sculpted Masonry Veneer	Sure Klean® Manufactured Stone Cleaner (1:2) or (1:3)	*Sure Klean® Weather Seal Blok-Guard® & Graffiti Control or Sure Klean® Weather Seal Siloxane WB Concentrate (1:9)	<u>Graffiti Repellent</u> * Sure Klean® Weather Seal Blok-Guard® & Graffiti Control OR Sure Klean® Weather Seal Blok-Guard® & Graffiti Control II <u>Graffiti Remover</u> Sure Klean® Fast Acting Stripper OR Defacer Eraser® Graffiti Wipe	<u>Color Enhancement</u> No Recommendation <u>Sheen Enhancement</u> No Recommendation
“Kasota” Sculpted Masonry Veneer	Sure Klean Manufactured Stone Cleaner (1:2) or (1:3) or Sure Klean® Custom Masonry Cleaner (1:2) or (1:4) or (1:6) or Sure Klean® Vana Trol® (1:6) or (1:8)	*Sure Klean® Weather Seal Blok-Guard® & Graffiti Control or Sure Klean® Weather Seal Siloxane WB Concentrate (1:9)	<u>Graffiti Repellent</u> * Sure Klean® Weather Seal Blok-Guard® & Graffiti Control <u>Graffiti Remover</u> Sure Klean® Fast Acting Stripper OR Defacer Eraser® Graffiti Wipe	<u>Color Enhancement</u> No Recommendation <u>Sheen Enhancement</u> No Recommendation

***NOTE:** Sure Klean® Weather Seal Blok-Guard® & Graffiti Control is manufactured and marketed in compliance with USEPA AIM VOC regulations (40 CFR 59.403). This product may not be suitable for sale in states and districts with more restrictive AIM VOC regulations.

Apply all products in accordance with the manufacturer’s recommendations provided on container labels and product data sheets. On-site testing should be conducted to determine the most appropriate cleaning, water repellent, or stain repellent products and procedures for a particular project. See product literature for additional application and safety information.