



AMT Laboratories
 3741 Greenway Circle
 Lawrence, KS 66046
 Phone: 888.376.3600
 Fax: 785.830.9176

Henry Brick Company
Project No. 0803-02 PTP

One type of clay brick was submitted to AMT Laboratories by PROSOCO, Inc. with a request to determine the optimal cleaning/cure time combination to most efficiently remove Type N mortar from the submitted clay brick while limiting surface alterations to the decorative finish. Additionally, the effectiveness of water repellents and graffiti control products suitable for clay brick was evaluated. **New Construction Cleaning** was performed to evaluate the effectiveness of the selected PROSOCO products at removing excess mortar, and related new construction soiling, while limiting potential surface alterations to the finish. **Protective Water Repellent** testing was performed to evaluate which PROSOCO water repellent(s) are most effective at providing protection from wind driven rain. **Graffiti Control** products were evaluated for its ability to repel and remove graffiti from the submitted samples. The attached report provides information about the PROSOCO products tested and descriptions of the test methods. The report includes test results as well as conclusions and recommendations. Recommendations are also provided in the chart below.

Recommendations

Sample	New Construction Cleaning Type N Mortar (21 Day Cleaning)	Protective Water Repellents	Graffiti Control
<p align="center">“Gleason Blend” Clay Brick</p>	<p align="center">Enviro Klean® Safety Klean (1:3) or Sure Klean® Vana Troi® (1:8)</p>	<p align="center">Sure Klean® Weather Seal Siloxane PD</p>	<p align="center"><u>Graffiti Repellents</u> Sure Klean® Weather Seal Blok-Guard® & Graffiti Control II</p> <p align="center"><u>Graffiti Removers</u> Sure Klean® Fast Acting Stripper or Defacer Eraser® Graffiti Wipe</p>

Apply all products in accordance with the manufacturer’s recommendations provided on container labels and product data sheets. On-site testing should be conducted to determine the most appropriate cleaning, water repellent, or stain repellent products and procedures for a particular project. See product literature for additional application and safety information.