



AMT Laboratories
 3741 Greenway Circle
 Lawrence, KS 66046
 Phone: 888.376.3600
 Fax: 785.830.9176

Xella AAC Texas, Inc.
Project No. 0804-01 PTP

Two types of autoclaved aerated concrete (AAC block) were submitted for testing to AMT Laboratories by PROSOCO, Inc. to determine the optimal concentration of cleaner which leaves the external surface looking most like the uncleaned surface of the AAC block. The effectiveness of protective water repellents and graffiti control products suitable for concrete block was also evaluated. **Limiting Surface Alterations** testing was performed to determine the limit of potential surface alterations to the finish. **Protective Water Repellent** testing was performed to evaluate which PROSOCO water repellent(s) are most effective at providing protection from wind driven rain. **Graffiti Control** products were evaluated for its ability to repel and remove graffiti from the submitted samples. The attached report provides information about the PROSOCO products tested and descriptions of the test methods. The report includes test results as well as conclusions and recommendations. Recommendations are also provided in the chart below.

Recommendations

Sample	Limiting Surface Alterations	Protective Water Repellents	Graffiti Control
AAC Block Ground	Sure Klean® Vana Trol® (1:8)	*Sure Klean® Weather Seal Blok-Guard® & Graffiti Control	<u>Graffiti Repellents</u> *Sure Klean® Weather Seal Blok-Guard® & Graffiti Control <u>Graffiti Removers</u> Sure Klean® Fast Acting Stripper or Defacer Eraser® Graffiti Wipe
AAC Block Smooth	Sure Klean® Vana Trol® (1:8)	*Sure Klean® Weather Seal Blok-Guard® & Graffiti Control or Sure Klean® Weather Seal Siloxane WB Concentrate (1:9)	<u>Graffiti Repellents</u> *Sure Klean® Weather Seal Blok-Guard® & Graffiti Control <u>Graffiti Removers</u> Sure Klean® Fast Acting Stripper or Defacer Eraser® Graffiti Wipe

***NOTE:** Sure Klean® Weather Seal Blok-Guard® & Graffiti Control is manufactured and marketed in compliance with USEPA AIM VOC regulations (40 CFR 59.403). This product may not be suitable for sale in states and districts with more restrictive AIM VOC regulations.

Apply all products in accordance with the manufacturer's recommendations provided on container labels and product data sheets. On-site testing should be conducted to determine the most appropriate cleaning, water repellent, or stain repellent products and procedures for a particular project. See product literature for additional application and safety information.