



AMT Laboratories
 3741 Greenway Circle
 Lawrence, KS 66046
 Phone: 888.376.3600
 Fax: 785.830.9176

Realstone Tempered Glazed Tiles

Executive Summary

Project No. 1805-05

Three types of tempered glazed tile samples were submitted to AMT Laboratories by PROSOCO, Inc. with a request to determine if application of the products evaluated will produce any surface alterations during new construction cleaning operations and standard maintenance cleaning operations. Additionally, cleaning testing was performed to evaluate which PROSOCO cleaner is most effective at removing adhesive residue left from protective wrapping on the surface of the glazed tiles.

The laboratory report (1805-05 Realstone Tempered Glazed Tiles) provides information about the PROSOCO products tested and descriptions of the test methods. The report includes test results as well as conclusions and recommendations. Recommendations are also provided in the chart below.

Recommendations

Sample	New Construction Cleaning (Removal of Excess Polymer Modified Grout)	Maintenance Cleaning	Removal of Adhesive Residue
"Ruby"	PROSOCO SafEtch® (use in concentrate or dilute up to 3 parts water)	Enviro Klean® 2010 All Surface Cleaner (use in concentrate or dilute up to 10 parts water)	PROSOCO Cleaner/Degreaser (1:4)
"Marine"	PROSOCO SafEtch® (use in concentrate or dilute up to 3 parts water)	Enviro Klean® 2010 All Surface Cleaner (use in concentrate or dilute up to 10 parts water)	PROSOCO Cleaner/Degreaser (1:4)
"Gunmetal"	PROSOCO SafEtch® (use in concentrate or dilute up to 3 parts water)	Enviro Klean® 2010 All Surface Cleaner (use in concentrate or dilute up to 10 parts water)	PROSOCO Cleaner/Degreaser (1:4)

Apply all products in accordance with the manufacturer's recommendation provided on container labels and product data sheets. On-site testing should be conducted to determine the most appropriate product and procedures for a particular project. See product literature for additional application and product information.