



AMT Laboratories
 3741 Greenway Circle
 Lawrence, KS 66046
 Phone: 888.376.3600
 Email: info@amt-labs.com

Wayne Builders Supply Executive Summary Project No. 1806-03

Two types of split-face CMUs were submitted to AMT Laboratories by PROSOCO, Inc. with a request to determine the most appropriate new construction cleaner for the CMUs. Additionally, the effectiveness of water repellent and graffiti resistance products suitable for CMUs was evaluated.

The laboratory report (1806-03 PTP Wayne Builders Supply) provides information about the PROSOCO products tested and descriptions of the test methods. The report includes test results as well as conclusions and recommendations. Recommendations are also provided in the chart below.

Recommendations

Sample	New Construction Cleaning	Water Repellency	Graffiti Resistance
"Ironwood"	Sure Klean® Custom Masonry Cleaner (1:4) or (1:6) Or Sure Klean® Light Duty Concrete Cleaner (1:2) or (1:3)	Sure Klean® Weather Seal Blok-Guard® & Graffiti Control II	<u>Graffiti Repellent</u> Sure Klean® Weather Seal Blok-Guard® & Graffiti Control II <u>Graffiti Removers</u> Enviro Klean® SafStrip® 8 or Defacer Eraser® Graffiti Remover
"Rockrose"	Sure Klean® Custom Masonry Cleaner (1:4) or (1:6) Or Sure Klean® Light Duty Concrete Cleaner (1:2) or (1:3)	Sure Klean® Weather Seal Blok-Guard® & Graffiti Control II	<u>Graffiti Repellent</u> Sure Klean® Weather Seal Blok-Guard® & Graffiti Control II <u>Graffiti Removers</u> Enviro Klean® SafStrip® 8 or Defacer Eraser® Graffiti Remover

Apply all products in accordance with the manufacturer's recommendation provided on container labels and product data sheets. On-site testing should be conducted to determine the most appropriate product and procedures for a particular project. See product literature for additional application and product information.