



ORIJIN STONE
Minneapolis, MN
Executive Summary
 Project No. 1809-25

Eighteen natural stone samples (3 Travertine, 6 Limestone, 7 Sandstone, 1 Granite, and 1 Basalt) were submitted to AMT Laboratories by PROSOCO, Inc. with a request to determine the most appropriate new construction cleaner. Additionally, water repellent and stain resistant products suitable for natural stone were evaluated.

The laboratory report (1809-25 PTP ORIJIN STONE) provides information about the PROSOCO® products tested and descriptions of the test methods. The report includes test results as well as conclusions and recommendations. Recommendations are also provided in the chart below.

Recommendations:

Sample	New Construction Cleaning	Water Repellency	Stain Repellent	Maintenance Cleaner
"Bisque" Travertine	Sure Klean® Light Duty Concrete Cleaner (1:2) or (1:3) OR Sure Klean® Vana Trol® (1:8) or (1:10) OR Enviro Klean® Safety Klean (1:2) or (1:3)	Sure Klean® Weather Seal Natural Stone Treatment OR Sure Klean® Weather Seal Natural Stone Treatment WB Plus	Stand Off® Limestone & Marble Protector OR Stand Off® Stone, Tile & Masonry Protector (STMP)	Enviro Klean® 2010 All Surface Cleaner (1:10)
"Walnut" Travertine	Sure Klean® Light Duty Concrete Cleaner (1:2) or (1:3) OR Sure Klean® Vana Trol® (1:8) or (1:10)			
"Percheron" Travertine	Sure Klean® Light Duty Concrete Cleaner (1:2) or (1:3) OR Sure Klean® Vana Trol® (1:8) or (1:10) OR Enviro Klean® Safety Klean (1:2) or (1:3) OR Enviro Klean® 2010 All Surface Cleaner (1:10)	Stand Off® Limestone & Marble Protector OR Stand Off® Stone, Tile & Masonry Protector (STMP)	² Stand Off® Limestone & Marble Protector OR ¹ Stand Off® Stone, Tile & Masonry Protector (STMP)	
"Ardeo" Limestone				
"Nantucket" Limestone				
"Tupelo" Limestone				
"Friesian" Limestone				
"Ferris" Limestone				
"Pewter" Limestone				

NOTE: "1" indicates the most effective treatment and "2" indicates the second most effective treatment.

Apply all products in accordance with the manufacturer's recommendation provided on container labels and product data sheets. On-site testing should be conducted to determine the most appropriate product and procedures for a particular project. See product literature for additional application and product information.



ORIJIN STONE
Minneapolis, MN
Executive Summary
 Project No. 1809-25

Recommendations: (cont.)

Sample	New Construction Cleaning	Water Repellency	Stain Repellent	Maintenance Cleaner
“Blue Select Thermal Bluestone” Sandstone	Sure Klean® Light Duty Concrete Cleaner (1:2) or (1:3) OR	Sure Klean® Weather Seal Natural Stone Treatment OR		
“Full Color Thermal Bluestone” Sandstone	Sure Klean® Vana Trol® (1:8) or (1:10) OR Enviro Klean® Safety Klean (1:2) or (1:3)	Sure Klean® Weather Seal Natural Stone Treatment WB Plus OR PROSOCO® SLX100® Water & Oil Repellent	¹ PROSOCO® SLX100® Water & Oil Repellent OR	
“Baltic Bluestone” Sandstone	Enviro Klean® Safety Klean (1:2) or (1:3)	Stand Off® Stone, Tile & Masonry Protector (STMP) OR	² Stand Off® Stone, Tile & Masonry Protector (STMP)	
“Connemara” Sandstone	Sure Klean® Light Duty Concrete Cleaner (1:2) or (1:3) OR	PROSOCO® Saltguard® OR		
“Greydon” Quartzitic Sandstone	Sure Klean® Vana Trol® (1:8) or (1:10) OR	PROSOCO® Saltguard® WB		
“Laurel” Quartzitic Sandstone	Enviro Klean® Safety Klean (1:2) or (1:3)			
“Hudson” Quartzitic Sandstone				
“Basalt”	Enviro Klean® 2010 All Surface Cleaner (1:10)	Sure Klean® Weather Seal Natural Stone Treatment OR PROSOCO® SLX100® Water & Oil Repellent OR PROSOCO® Saltguard® OR PROSOCO® Saltguard® WB	PROSOCO® SLX100® Water & Oil Repellent	Enviro Klean® 2010 All Surface Cleaner (1:10)
“Harbor” Granite	Sure Klean® Light Duty Concrete Cleaner (1:2) or (1:3) OR Sure Klean® Vana Trol® (1:8) or (1:10) OR Enviro Klean® Safety Klean (1:2) or (1:3)	Sure Klean® Weather Seal Natural Stone Treatment OR PROSOCO® SLX100® Water & Oil Repellent OR Stand Off® Stone, Tile & Masonry Protector (STMP) OR PROSOCO® Saltguard® OR PROSOCO® Saltguard® WB	² PROSOCO® SLX100® Water & Oil Repellent OR ¹ Stand Off® Stone, Tile & Masonry Protector (STMP)	

NOTE: “1” indicates the most effective treatment and “2” indicates the second most effective treatment.

Apply all products in accordance with the manufacturer's recommendation provided on container labels and product data sheets. On-site testing should be conducted to determine the most appropriate product and procedures for a particular project. See product literature for additional application and product information.