



**Hebron Brick**  
**Hebron, ND**  
**Executive Summary**  
 Project No. 1901-02

Thirteen types of clay brick were submitted to AMT Laboratories by PROSOCO, Inc. with a request to determine the most appropriate new construction cleaner.

The laboratory report (1901-02 PTP Hebron Brick) provides information about the PROSOCO® products tested and descriptions of the test methods. The report includes test results as well as conclusions and recommendations. Recommendations are also provided in the chart below.

Refer to report 1812-01 PTP Hebron Brick for new construction cleaning recommendations for “Overture” brick.

**Recommendations:**

| Sample         | New Construction Cleaning  |
|----------------|--|
| “Champagne”    | Sure Klean® 600 Detergent (1:6) or (1:8)<br>OR<br>Sure Klean® Vana Trol® (1:6) or (1:8)<br>OR<br>Use Enviro Klean® Safety Klean (1:2) or (1:3) |
| “Buckwheat”    |  |
| “Scoria”       |  |
| “Silverado”    |  |
| “Toasted Gray” |  |
| “Onyx”         |  |
| “Opus”         |  |
| “Garnet”       |  |
| “Rosemont”     |  |
| “Walnut Creek” |  |
| “Castlewood”   |  |
| “Brandywine”   |  |
| “Madison”      |  |

Apply all products in accordance with the manufacturer's recommendation provided on container labels and product data sheets. On-site testing should be conducted to determine the most appropriate product and procedures for a particular project. See product literature for additional application and product information.