



Shaw Brick – Clay Brick
Lantz, Nova Scotia, Canada
Executive Summary
 Project No. 1902-01

Fifteen types of clay brick were submitted to AMT Laboratories by PROSOCO, Inc. with a request to determine the most appropriate new construction cleaner. Additionally, water repellent and graffiti resistant products suitable for the samples were evaluated.

The laboratory report (1902-01 PTP Shaw Brick – Clay Brick) provides information about the PROSOCO® products tested and descriptions of the test methods. The report includes test results as well as conclusions and recommendations. Recommendations are also provided in the chart below.

Recommendations:

| Sample | New Construction Cleaning | Water Repellency | Graffiti Resistance |
|------------------------------|--|---|--|
| "Tapestry Red" Brick | Sure Klean® Vana Trol® (1:6) or (1:8) OR Sure Klean® 600 Detergent (1:6) or (1:8) OR Enviro Klean® Safety Klean (1:2) or (1:3) | Sure Klean® Weather Seal Siloxane PD OR Sure Klean® Weather Seal Blok-Guard® & Graffiti Control II OR Sure Klean® Weather Seal Blok-Guard® & Graffiti Control Ultra | <p style="text-align: center;"><u>Graffiti Repellent</u> ¹Sure Klean® Weather Seal Blok-Guard® & Graffiti Control Ultra OR ²Sure Klean® Weather Seal Blok-Guard® & Graffiti Control II</p> <p style="text-align: center;"><u>Graffiti Removers</u> ¹Defacer Eraser® Graffiti Remover OR ²Enviro Klean® Safstrip®</p> |
| "Tapestry Buff" | Enviro Klean® Safety Klean (1:2) or (1:3) | | |
| "Tapestry Brown" Brick | Sure Klean® Vana Trol® (1:6) or (1:8) OR Sure Klean® 600 Detergent (1:6) or (1:8) OR Enviro Klean® Safety Klean (1:2) or (1:3) | | |
| "Tapestry Manganese" Brick | | | |
| "Tapestry Red Flashed" Brick | | | |
| "Tweedtex Red" Brick | | | |
| "Tweedtex Buff" Brick | | | |
| "Tweedtex Brown" Brick | | N/A* | |

***NOTE: Due to the irregular surface texture present, water absorption tube testing was unable to be performed.**

NOTE: "1" indicates the most effective product and "2" indicates the second most effective product.

Apply all products in accordance with the manufacturer's recommendation provided on container labels and product data sheets. On-site testing should be conducted to determine the most appropriate product and procedures for a particular project. See product literature for additional application and product information.



Shaw Brick – Clay Brick
Lantz, Nova Scotia, Canada
Executive Summary
 Project No. 1902-01

Recommendations:

| Sample | New Construction Cleaning | Water Repellency | Water Repellency | Graffiti Resistance |
|------------------------------|--|---|---|---|
| “Smooth Red” Brick | Sure Klean® Vana Trol® (1:6) or (1:8) OR Sure Klean® 600 Detergent (1:6) or (1:8) OR Enviro Klean® | Sure Klean® Weather Seal Siloxane PD OR Sure Klean® Weather Seal Blok-Guard® & Graffiti Control II | Sure Klean® Weather Seal Siloxane PD OR Sure Klean® Weather Seal Blok-Guard® & Graffiti Control II OR Sure Klean® Weather Seal Blok-Guard® & Graffiti Control Ultra | <p style="text-align: center;"><u>Graffiti Repellent</u></p> ¹ Sure Klean® Weather Seal Blok-Guard® & Graffiti Control Ultra OR ² Sure Klean® Weather Seal Blok-Guard® & Graffiti Control II <p style="text-align: center;"><u>Graffiti Removers</u></p> ¹ Defacer Eraser® Graffiti Remover OR ² Enviro Klean® Safstrip® |
| “Smooth Buff” Brick | Sure Klean® Vana Trol® (1:6) or (1:8) OR Enviro Klean® Safety Klean (1:2) or (1:3) | Sure Klean® Weather Seal Blok-Guard® & Graffiti Control II OR Sure Klean® Weather Seal Blok-Guard® & Graffiti Control Ultra | | |
| “Smooth Manganese” Brick | Sure Klean® Vana Trol® (1:6) or (1:8) OR Sure Klean® 600 Detergent (1:6) or (1:8) OR Enviro Klean® Safety Klean (1:2) or (1:3) | Sure Klean® Weather Seal Siloxane PD OR Sure Klean® Weather Seal Blok-Guard® & Graffiti Control II | | |
| “Port Morien” Brick | Enviro Klean® Safety Klean (1:2) or (1:3) | Sure Klean® Weather Seal Siloxane PD OR Sure Klean® Weather Seal Blok-Guard® & Graffiti Control II | | |
| “Atlantic White Point” Brick | Sure Klean® Vana Trol® (1:6) or (1:8) OR Sure Klean® 600 Detergent (1:6) or (1:8) OR Enviro Klean® Safety Klean | Sure Klean® Weather Seal Blok-Guard® & Graffiti Control II OR Sure Klean® Weather Seal Blok-Guard® & Graffiti Control Ultra | | |
| “Highland Kirkhill” Brick | | | | |
| “Antique Colonial” Brick | | | | |

NOTE: “1” indicates the most effective product and “2” indicates the second most effective product.

Apply all products in accordance with the manufacturer's recommendation provided on container labels and product data sheets. On-site testing should be conducted to determine the most appropriate product and procedures for a particular project. See product literature for additional application and product information.