



Spectra Glaze®
Executive Summary
 Project No. 1902-02

Four types of SPECTRA-GLAZE® II CMUs were submitted to AMT Laboratories by PROSOCO, Inc. with a request to determine the most appropriate new construction cleaner. Additionally, graffiti removal products suitable for these samples were evaluated.

The laboratory report (1902-02 PTP Spectra Glaze®) provides information about the PROSOCO® products tested and descriptions of the test methods. The report includes test results as well as conclusions and recommendations. Recommendations are also provided in the chart below.

Recommendations:

Sample	New Construction Cleaning	Graffiti Removal
"Custom Red" SPECTRA-GLAZE® II CMU	Sure Klean® Vana Trol® (1:6) or (1:8) OR Enviro Klean® 2010 All Surface Cleaner (Concentrate) or (1:10)	Defacer Eraser® Graffiti Remover OR Enviro Klean® SafStrip®
"Charcoal A" SPECTRA-GLAZE® II CMU		
"Light Leaf Green" SPECTRA-GLAZE® II CMU		
"Stormy Gray" SPECTRA-GLAZE® II CMU		

Apply all products in accordance with the manufacturer's recommendation provided on container labels and product data sheets. On-site testing should be conducted to determine the most appropriate product and procedures for a particular project. See product literature for additional application and product information.