



Bowerston Shale Company
Hanover, OH
Executive Summary
 Project No. 1903-03

Six types of clay brick were submitted to AMT Laboratories by PROSOCO, Inc. with a request to determine the most appropriate new construction cleaner. Additionally, color and sheen enhancement, water repellent, graffiti resistance, and stain repellent products suitable for the samples were evaluated.

The laboratory report (1903-03 PTP Bowerston Shale Company) provides information about the PROSOCO® products tested and descriptions of the test methods. The report includes test results as well as conclusions and recommendations. Recommendations are also provided in the chart below.

Recommendations:

Sample	New Construction Cleaning	Color and Sheen Enhancement	Water Repellency	Graffiti Resistance	Stain Repellency	Maintenance Cleaner
"Desert Sage WC" Brick	Sure Klean® Vana Trof® (1:6) or (1:8) OR Sure Klean® 600 Detergent (1:6) or (1:8)	Sure Klean® Weather Seal Blok-Guard® & Graffiti Control Ultra OR Stand Off® Gloss 'N Guard	Sure Klean® Weather Seal Siloxane PD OR Sure Klean® Weather Seal Blok-Guard® & Graffiti Control Ultra OR Stand Off® Gloss 'N Guard OR PROSOCO® SLX100® Water & Oil Repellent	<u>Graffiti Repellent</u> Sure Klean® Weather Seal Blok-Guard® & Graffiti Control Ultra <u>Graffiti Removers</u> ¹ Defacer Eraser® Graffiti Remover OR ² Enviro Klean® Safstrip®	<u>Stain Repellency</u> ¹ PROSOCO® SLX100® Water & Oil Repellent OR ² Stand Off® Gloss 'N Guard <u>Maintenance Cleaner</u> Enviro Klean® 2010 All Surface Cleaner (1:10)	Enviro Klean® 2010 All Surface Cleaner (1:10)
"Harvest Blend" Brick*						
"#130" Brick						
"#445" Brick						
"#501" Brick						
"#940" Brick						

*The sandy surface finish on the "Harvest Blend" brick is removed with the mechanical action of a brush. This surface finish removal does not change the appearance of the brick.

NOTE: "1" indicates the most effective product and "2" indicates the second most effective product.

Apply all products in accordance with the manufacturer's recommendation provided on container labels and product data sheets. On-site testing should be conducted to determine the most appropriate product and procedures for a particular project. See product literature for additional application and product information.