



Coronado Stone Products
Simpsonville, SC
Executive Summary
 Project No. 1903-04

Six types of manufactured stone were submitted to AMT Laboratories by PROSOCO, Inc. with a request to determine the most appropriate new construction cleaner. Additionally, the effectiveness of water repellent products suitable for manufactured stone were evaluated.

The laboratory report (1903-04 PTP Coronado Stone Products) provides information about the PROSOCO® products tested and descriptions of the test methods. The report includes test results as well as conclusions and recommendations. Recommendations are also provided in the chart below.

Recommendations:

Sample	New Construction Cleaning	Water Repellency
"French White French Limestone"	Sure Klean® Light Duty Concrete Cleaner (1:2) or (1:3) OR Sure Klean® Vana Trol® (1:8) OR Enviro Klean® 2010 All Surface Cleaner (1:10)	Sure Klean® Weather Seal Siloxane PD OR Sure Klean® Weather Seal Siloxane WB Concentrate (1:9) OR PROSOCO® SLX100® Water & Oil Repellent
"Country Beige French Limestone"	Sure Klean® Light Duty Concrete Cleaner (1:2) or (1:3) OR Enviro Klean® 2010 All Surface Cleaner (1:10)	
"Black Forest French Limestone"	Sure Klean® Light Duty Concrete Cleaner (1:2) or (1:3) OR Sure Klean® Vana Trol® (1:8) OR Enviro Klean® 2010 All Surface Cleaner (1:10)	
"Antique Cream Old World Ledge"	Sure Klean® Light Duty Concrete Cleaner (1:2) or (1:3) OR Enviro Klean® 2010 All Surface Cleaner (1:10)	
"Etowah Old World Ledge"	Enviro Klean® 2010 All Surface Cleaner (1:10)	
"Huron Old World Ledge"	Sure Klean® Light Duty Concrete Cleaner (1:2) or (1:3) OR Enviro Klean® 2010 All Surface Cleaner (1:10)	

Apply all products in accordance with the manufacturer's recommendation provided on container labels and product data sheets. On-site testing should be conducted to determine the most appropriate product and procedures for a particular project. See product literature for additional application and product information.