

Indiana Limestone Company Bloomington, IN

Executive Summary Project No. 1903-05

One type of limestone was submitted to AMT Laboratories by PROSOCO, Inc. with a request to determine the most appropriate new construction cleaner. Additionally, water repellent, graffiti resistant, and stain repellent products suitable for the samples were evaluated.

The laboratory report (1903-05 PTP Indiana Limestone Company) provides information about the PROSOCO® products tested and descriptions of the test methods. The report includes test results as well as conclusions and recommendations. Recommendations are also provided in the chart below.

Recommendations:

Sample	New Construction Cleaning	Water Repellency	Graffiti Resistance	Stain Repellency
Indiana Limestone	Sure Klean® Vana Trol® (1:6) or (1:8)	Sure Klean® Weather Seal Natural Stone Treatment WB Plus OR Stand Off® Limestone & Marble Protector OR Sure Klean® Weather Seal Blok-Guard® & Graffiti Control 15 OR Sure Klean® Weather Seal Blok-Guard® & Graffiti Control Ultra 15	Graffiti Repellent 1 Sure Klean® Weather Seal Blok- Guard® & Graffiti Control Ultra 15 OR 2 Sure Klean® Weather Seal Blok- Guard® & Graffiti Control 15 Graffiti Removers 1 Enviro Klean® Safstrip® 8 OR 2 Defacer Eraser® Graffiti Remover	Stain Repellency 1Stand Off® Stain Barrier OR 2Stand Off® Stone, Tile & Masonry Protector (STMP) OR 3Stand Off® Limestone & Marble Protector Maintenance Cleaner Enviro Klean® 2010 All Surface Cleaner (1:10)

NOTE: "1" indicates the most effective product, "2" indicates the second most effective product, and "3" indicates the third most effective product.

Apply all products in accordance with the manufacturer's recommendation provided on container labels and product data sheets. On-site testing should be conducted to determine the most appropriate product and procedures for a particular project. See product literature for additional application and product information.