



Acme Brick Company
Fort Worth, TX
Executive Summary
Project No. 1903-07

One type of Glazed Acme TC Cladding Terracotta Panel with an Engobe Finish was submitted to AMT Laboratories by PROSOCO, Inc. with a request to determine the most appropriate maintenance cleaner and graffiti removal product. Additionally, the effectiveness of the terracotta panel at repelling water and stains was evaluated.

The laboratory report (1903-07 PTP Acme Brick Company) provides information about the PROSOCO® products tested and descriptions of the test methods. The report includes test results as well as conclusions and recommendations. Recommendations are also provided in the chart below.

Recommendations:

Sample	Maintenance Cleaning	Graffiti Removal
Glazed Acme TC Cladding Terracotta Panels with an Engobe Finish	Enviro Klean® 2010 All Surface Cleaner (1:10)	Enviro Klean® SafStrip® OR Defacer Eraser® Graffiti Remover

Apply all products in accordance with the manufacturer's recommendation provided on container labels and product data sheets. On-site testing should be conducted to determine the most appropriate product and procedures for a particular project. See product literature for additional application and product information.