



Extech Building Materials
Long Island City, NY
Executive Summary
 Project No. 1904-06

Seven types of clay brick were submitted to AMT Laboratories by PROSOCO, Inc. with a request to determine the most appropriate new construction cleaner. Additionally, water repellent and graffiti resistance products suitable for the samples were evaluated.

The laboratory report (1904-06 PTP Extech Building Materials) provides information about the PROSOCO® products tested and descriptions of the test methods. The report includes test results as well as conclusions and recommendations. Recommendations are also provided in the chart below.

Recommendations:

Sample	New Construction Cleaning	Water Repellency	Graffiti Resistance
"Bedford JB Exton – JB. 8" Brick	Sure Klean® Vana Trol® (1:6) or (1:8) OR Sure Klean® 600 Detergent (1:6) or (1:8)	Sure Klean® Weather Seal Siloxane PD OR Sure Klean® Weather Seal Siloxane WB (1:9) OR Sure Klean® Weather Seal Blok-Guard® & Graffiti Control OR Sure Klean® Weather Seal Blok-Guard® & Graffiti Control Ultra 15	Graffiti Repellent ² Sure Klean® Weather Seal Blok-Guard® & Graffiti Control OR ¹ Sure Klean® Weather Seal Blok-Guard® & Graffiti Control Ultra 15 Graffiti Removers Defacer Eraser® Graffiti Remover
"Burgundy Matt STD" Brick			
"Exton – JB. 8" Brick			
"Mohawk Jumbo Molded" Brick			
"Mohawk STD Molded" Brick			
"Patriot STD Molded" Brick			
"Sturbridge Flash STD Cord Extruded" Brick			

NOTE: "1" indicates the most effective product and "2" indicates the second most effective product.

Please refer to the Product Data Sheet or visit www.prosoco.com/voccompliance to confirm VOC compliance with individual district or state regulations.

Apply all products in accordance with the manufacturer's recommendation provided on container labels and product data sheets. On-site testing should be conducted to determine the most appropriate product and procedures for a particular project. See product literature for additional application and product information.