



Bowerston Shale Company
Bowerston, OH
Executive Summary
Project No. 2001-09

Three types of clay brick were submitted to AMT Laboratories by PROSOCO, Inc. with a request to determine the most appropriate new construction cleaner. Additionally, color and sheen enhancement, water repellent, graffiti resistance, and stain repellent products suitable for the samples were evaluated.

The laboratory report (2001-09 PTP Bowerston Shale Company) provides information about the PROSOCO® products tested and descriptions of the test methods. The report includes test results as well as conclusions and recommendations. Recommendations are also provided in the chart below.

Recommendations:

Sample	New Construction Cleaning	Color and Sheen Enhancement	Water Repellency	Graffiti Resistance	Stain Repellency	Maintenance Cleaner
"Autumn Blend SM IS" Brick	Sure Klean® Vana Trol® (1:6) or (1:8)	Sure Klean® Weather Seal Blok-Guard® & Graffiti Control Ultra OR Stand Off® Gloss 'N Guard	Sure Klean® Weather Seal Siloxane PD OR Sure Klean® Weather Seal Blok-Guard® & Graffiti Control Ultra OR Stand Off® Gloss 'N Guard OR PROSOCO® SLX100® Water & Oil Repellent	<u>Graffiti Repellent</u> Sure Klean® Weather Seal Blok-Guard® & Graffiti Control Ultra <u>Graffiti Removers</u> ¹ Defacer Eraser® Graffiti Remover OR ² Enviro Klean® Safstrip®	<u>Stain Repellency</u> ¹ PROSOCO® SLX100® Water & Oil Repellent OR ² Stand Off® Gloss 'N Guard <u>Maintenance Cleaner</u> Enviro Klean® 2010 All Surface Cleaner (1:10)	Enviro Klean® 2010 All Surface Cleaner (1:10)
"#610" Brick						
"#940-1 SM IS" Brick						

NOTE: "1" indicates the most effective product and "2" indicates the second most effective product.

Apply all products in accordance with the manufacturer's recommendation provided on container labels and product data sheets. On-site testing should be conducted to determine the most appropriate product and procedures for a particular project. See product literature for additional application and product information.