



US Stone Industries
Manhattan, KS
Executive Summary
 Project No. 2003-04

Fourteen types of limestone were submitted to AMT Laboratories by PROSOCO, Inc. with a request to determine the most appropriate new construction cleaner.

The laboratory report (2003-04 PTP US Stone Industries) provides information about the PROSOCO® products tested and descriptions of the test methods. The report includes test results as well as conclusions and recommendations. Recommendations are also provided in the chart below.

Recommendations:

Sample	New Construction Cleaning
"Bottom Ledge Cottonwood Honed"	Sure Klean® Vana Trol® (1:6) or (1:8) OR Sure Klean® Light Duty Concrete Cleaner (1:2) or (1:3) OR Enviro Klean® Safety Klean (1:2) or (1:3)
"Top Ledge Cottonwood Honed"	
"Silverdale Honed"	
"Onaga Honed"	
"Prairie Shell Honed"	
"Flint Hills Gray Honed"	
"Plaza Gray Honed"	
"Cottonwood Split"	
"Silverdale Split"	
"Onaga Split"	
"Prairie Shell Split"	
"Flint Hills Mottled Split"	
"Flint Hills Gray Split"	
"Plaza Gray Split"	

Apply all products in accordance with the manufacturer's recommendation provided on container labels and product data sheets. On-site testing should be conducted to determine the most appropriate product and procedures for a particular project. See product literature for additional application and product information.