



**Galantino Supply Co., Inc.**  
**Springfield, PA**  
**Executive Summary**  
 Project No. 2102-03

Five types of natural stone samples were submitted to AMT Laboratories by PROSOCO, Inc. with a request to determine the most appropriate stain resistant product. Additionally, color and sheen enhancement and water repellency were evaluated for the selected products suitable for natural stone.

The laboratory report (2102-03 PTP Galantino Supply Co., Inc.) provides information about the PROSOCO, Inc. products tested and descriptions of the test methods. The report includes test results as well as conclusions and recommendations. Recommendations are also provided in the chart below.

**Recommendations:**

Sample	Color and Sheen Enhancement	Water Repellency	Stain Resistance
"Autumn Brown" – Quartzite	PROSOCO® SLX100® Water & Oil Repellent (Resulted in slight color enhancement)	PROSOCO® SLX100® Water & Oil Repellent OR Sure Klean® Weather Seal Stone, Tile & Masonry Protector (STMP)	<u><b>Stain Repellents</b></u> <sup>1</sup> PROSOCO® SLX100® Water & Oil Repellent OR <sup>2</sup> Sure Klean® Weather Seal Stone, Tile & Masonry Protector (STMP)  <u><b>Maintenance Cleaner</b></u> Enviro Klean® 2010 All Surface Cleaner (1:10)
"Brown Wave" – Sandstone	Neither product caused any color or sheen enhancement.		
"Pennsylvania Black Granite" – Granite			
"Pennsylvania Bluestone" – Sandstone			
"West Mountain" – Quartzitic Sandstone			

NOTE: "1" indicates the most effective product and "2" indicates the second most effective product.

Apply all products in accordance with the manufacturer's recommendation provided on container labels and product data sheets. On-site testing should be conducted to determine the most appropriate product and procedures for a particular project. See product literature for additional application and product information.