



**Semco Outdoor  
Belton, MO  
Executive Summary  
Project No. 2102-05**

Eight types of natural stone were submitted to AMT Laboratories by PROSOCO, Inc. with a request to determine the most appropriate new construction cleaner. Additionally, maintenance cleaner, color and sheen enhancement, water repellent, and stain resistant products suitable for the natural stone were evaluated.

The laboratory report (2102-05 PTP Semco Outdoor) provides information about the PROSOCO® products tested and descriptions of the test methods. The report includes test results as well as conclusions and recommendations. Recommendations are also provided in the chart below.

**Recommendations:**

Sample	New Construction Cleaning	Maintenance Cleaning	Color and Sheen Enhancement	Water Repellency	Graffiti Resistance
"Country Classic" Travertine	Sure Klean® Vana Trol® (1:6) or (1:8) OR Enviro Klean® Safety Klean (1:2) or (1:3)	Enviro Klean® Klean 'N Release Cleaner (1:10)	Please refer to pages 21-30 of the report for individual recommendations based on the desired result.	Sure Klean® Weather Seal Limestone & Marble Protector OR Sure Klean® Weather Seal Stone Tile & Masonry Protector (STMP) OR Sure Klean® Weather Seal Paver Enhancer OR Sure Klean® Weather Seal Natural Stone Treatment OR Sure Klean® Weather Seal Natural Stone Treatment VOC	<p style="text-align: center;"><b><u>Stain Repellents</u></b> Sure Klean® Weather Seal Limestone &amp; Marble Protector OR Sure Klean® Weather Seal Stone Tile &amp; Masonry Protector (STMP)</p> <p style="text-align: center;"><b><u>Maintenance Cleaner</u></b> Enviro Klean® Klean 'N Release Cleaner (1:10)</p>
"Ivory" Travertine					
"Leonardo" Travertine					
"Noce" Travertine					
"Pacific Silver" Travertine					

Apply all products in accordance with the manufacturer's recommendation provided on container labels and product data sheets. On-site testing should be conducted to determine the most appropriate product and procedures for a particular project. See product literature for additional application and product information.



**Semco Outdoor  
Belton, MO  
Executive Summary  
Project No. 2102-05**

**Recommendations:**

Sample	New Construction Cleaning	Maintenance Cleaning	Color and Sheen Enhancement	Water Repellency	Graffiti Resistance
“Dove Gray” Limestone	Sure Klean® Vana Trol® (1:6) or (1:8) OR Enviro Klean® Safety Klean (1:2) or (1:3)	Enviro Klean® Klean ‘N Release Cleaner (1:10)	Please refer to pages 21-30 of the report for individual recommendations based on the desired result.	Sure Klean® Weather Seal Limestone & Marble Protector OR Sure Klean® Weather Seal Stone Tile & Masonry Protector (STMP) OR Sure Klean® Weather Seal Paver Enhancer OR Sure Klean® Weather Seal Natural Stone Treatment OR Sure Klean® Weather Seal Natural Stone Treatment VOC	<b><u>Stain Repellents</u></b> Sure Klean® Weather Seal Limestone & Marble Protector OR Sure Klean® Weather Seal Stone Tile & Masonry Protector (STMP)
“Mountain Ridge” Dolomitic Limestone				<b><u>Maintenance Cleaner</u></b> Enviro Klean® Klean ‘N Release Cleaner (1:10)	
“Black Hills” Sandstone				<b><u>Stain Repellents</u></b> PROSOCO® SLX100® Water & Oil Repellent OR Sure Klean® Weather Seal Stone Tile & Masonry Protector (STMP) OR Sure Klean® Weather Seal Paver Enhancer OR Sure Klean® Weather Seal Natural Stone Treatment OR Sure Klean® Weather Seal Natural Stone Treatment VOC	<b><u>Maintenance Cleaner</u></b> Enviro Klean® Klean ‘N Release Cleaner (1:10)

Apply all products in accordance with the manufacturer's recommendation provided on container labels and product data sheets. On-site testing should be conducted to determine the most appropriate product and procedures for a particular project. See product literature for additional application and product information.