



**Rivard Stone  
Houlton, WI  
Executive Summary  
Project No. 2104-03**

Four types of natural stone were submitted to AMT Laboratories by PROSOCO, Inc. with a request to determine the most appropriate new construction cleaner and maintenance cleaner. Additionally, stain removal (adverse effects), color and sheen enhancement, water repellent, and stain resistant products suitable for natural stone were evaluated.

The laboratory report (2104-03 PTP Rivard Stone) provides information about the PROSOCO® products tested and descriptions of the test methods. The report includes test results as well as conclusions and recommendations. Recommendations are also provided in the chart below.

**Recommendations:**

Sample	New Construction Cleaning	Maintenance Cleaning	Adverse Effects	Color and Sheen Enhancement	Water Repellency	Stain Resistance
“St. Croix Valley – Cream” Limestone	Sure Klean® Vana Trol® (1:6) or (1:8) OR Sure Klean® Light Duty Concrete Cleaner (1:2) or (1:3) OR Enviro Klean® Safety Klean (1:2) or (1:3)	Enviro Klean® Klean ‘N Release Cleaner (1:10)	PROSOCO® T2683 Efflorescence Remover	Please refer to pages 22-27 of the report for individual recommendations based on the desired result.	Sure Klean® Weather Seal Limestone & Marble Protector OR Sure Klean® Weather Seal Stone Tile & Masonry Protector (STMP) OR Sure Klean® Weather Seal Natural Stone Treatment OR Sure Klean® Weather Seal Natural Stone Treatment WB Plus OR Sure Klean® Weather Seal Paver Enhancer	Sure Klean® Weather Seal Limestone & Marble Protector OR Sure Klean® Weather Seal Stone Tile & Masonry Protector (STMP)
“St. Croix Valley – Buff” Limestone	Enviro Klean® Safety Klean (1:2) or (1:3)					

Apply all products in accordance with the manufacturer's recommendation provided on container labels and product data sheets. On-site testing should be conducted to determine the most appropriate product and procedures for a particular project. See product literature for additional application and product information.



**Rivard Stone  
Houlton, WI  
Executive Summary  
Project No. 2104-03**

**Recommendations:**

Sample	New Construction Cleaning	Maintenance Cleaning	Adverse Effects	Color and Sheen Enhancement	Water Repellency	Stain Resistance
“St. Croix Valley – Stillwater Blend” Limestone	Sure Klean® Vana Trol® (1:6) or (1:8) OR Sure Klean® Light Duty Concrete Cleaner (1:2) or (1:3) OR Enviro Klean® Safety Klean (1:2) or (1:3)	Enviro Klean® Klean ‘N Release Cleaner (1:10)	PROSOCO® T2683 Efflorescence Remover	Please refer to pages 22-27 of the report for individual recommendations based on the desired result.	Sure Klean® Weather Seal Limestone & Marble Protector OR Sure Klean® Weather Seal Stone Tile & Masonry Protector (STMP) OR Sure Klean® Weather Seal Natural Stone Treatment OR Sure Klean® Weather Seal Natural Stone Treatment WB Plus OR Sure Klean® Weather Seal Paver Enhancer	N/A
“Iron Mountain” Basalt					PROSOCO® SLX100® Water & Oil Repellent OR Sure Klean® Weather Seal Natural Stone Treatment OR Sure Klean® Weather Seal Paver Enhancer	

Apply all products in accordance with the manufacturer's recommendation provided on container labels and product data sheets. On-site testing should be conducted to determine the most appropriate product and procedures for a particular project. See product literature for additional application and product information.