



Fizzano Brothers Concrete Products

Malvern, PA

Executive Summary

Project No. 2104-04

Three types of CMUs and one Spec-Brik® were submitted to AMT Laboratories by PROSOCO, Inc. with a request to determine the most appropriate new construction cleaner. Additionally, color and sheen enhancement, water repellent, and graffiti resistant products suitable for CMUs were evaluated.

The laboratory report (2104-04 PTP Fizzano Brothers Concrete Products) provides information about the PROSOCO® products tested and descriptions of the test methods. The report includes test results as well as conclusions and recommendations. Recommendations are also provided in the chart below.

Recommendations:

Sample	New Construction Cleaning	Color and Sheen Enhancement	Water Repellency	Graffiti Resistance
“Mix Design A” Split Face CMU	Sure Klean® Vana Trol® (1:6) or (1:8) OR Sure Klean® Custom Masonry Cleaner (1:4) or (1:6) OR Sure Klean® Light Duty Concrete Cleaner (1:2) or (1:3)	Sure Klean® Weather Seal Blok-Guard® & Graffiti Control Ultra (Recommended if moderate color enhancement is desired) OR Sure Klean® Weather Seal Blok-Guard® & Graffiti Control II (Recommended if slight color enhancement is desired) OR Sure Klean® Weather Seal Siloxane WB Concentrate (1:9) (Recommended if zero to slight color enhancement is desired)	Sure Klean® Weather Seal Blok-Guard® & Graffiti Control Ultra OR Sure Klean® Weather Seal Blok-Guard® & Graffiti Control II OR Sure Klean® Weather Seal Siloxane WB Concentrate (1:9)	<p><u>Graffiti Repellents</u></p> ¹ Sure Klean® Weather Seal Blok-Guard® & Graffiti Control Ultra OR ² Sure Klean® Weather Seal Blok-Guard® & Graffiti Control II
“Mix Design B” Blast Finish CMU				<p><u>Graffiti Removers</u></p> ¹ Sure Klean® Graffiti Remover OR ² Enviro Klean® SafStrip® 8
“Mix Design C” Ground Face CMU				
“Mix Design D” Spec-Brik®				

NOTE: “1” indicates the most effective product and “2” indicates the second most effective product.

Apply all products in accordance with the manufacturer's recommendation provided on container labels and product data sheets. On-site testing should be conducted to determine the most appropriate product and procedures for a particular project. See product literature for additional application and product information.