

## Brock White Construction Materials Burnaby, BC, Canada

## **Executive Summary**

Project No. 2108-02

One type of clay brick was submitted to AMT Laboratories by PROSOCO, Inc. with a request to determine the most appropriate new construction cleaner. Additionally, color and sheen enhancement, water repellent, and graffiti resistant products suitable for clay brick were evaluated.

The laboratory report (2108-02 PTP Brock White Construction Materials) provides information about the PROSOCO® products tested and descriptions of the test methods. The report includes test results as well as conclusions and recommendations. Recommendations are also provided in the chart below.

## Recommendations:

Sample	New Construction Cleaning	Color and Sheen Enhancement	Water Repellency	Graffiti Resistance
"Contemporary White - Smooth" Brick	Sure Klean® Vana Trol® (1:4) or (1:6) or (1:8) OR Enviro Klean® Safety Klean (1:2) or (1:3)	Sure Klean® Weather Seal Siloxane PD (Recommended if zero enhancement is desired) OR Sure Klean® Weather Seal Blok-Guard® & Graffiti Control Ultra (Recommended if zero enhancement is desired) OR PROSOCO T2676 Graffiti Control WB 15 (Recommended if zero enhancement is desired) Follow treatment	Sure Klean® Weather Seal Siloxane PD OR Sure Klean® Weather Seal Blok-Guard® & Graffiti Control Ultra OR PROSOCO T2676 Graffiti Control WB 15	Graffiti Repellents  1PROSOCO T2676 Graffiti Control WB 15 OR  2Sure Klean® Weather Seal Blok-Guard® & Graffiti Control Ultra  Graffiti Removers Enviro Klean® SafStrip® OR Sure Klean® Graffiti Remover  ense surfaces.

NOTE: "1" indicates the most effective product and "2" indicates the second most effective product.

Apply all products in accordance with the manufacturer's recommendation provided on container labels and product data sheets. On-site testing should be conducted to determine the most appropriate product and procedures for a particular project. See product literature for additional application and product information.