



Quarra Stone Company
Madison, WI
Executive Summary
 Project No. 2108-03

Eleven types of natural stone were submitted to AMT Laboratories by PROSOCO, Inc. with a request to determine the effectiveness of appropriate PROSOCO, Inc. products in removing the orange staining from the submitted “Vals Grey – C120 Honed” quartzite samples. Additionally, color and sheen enhancement and stain resistant products suitable for all the submitted natural stone were evaluated.

The laboratory report (2108-03 PTP Quarra Stone Company) provides information about the PROSOCO, Inc. products tested and descriptions of the test methods. The report includes test results as well as conclusions and recommendations. Recommendations are also provided in the chart below.

Recommendations:

Sample	Orange Stain Removal	Stain Resistance
“Vals Green Eyes – C120 Honed” Quartzite	N/A	Stain Repellents ¹ Sure Klean® Gloss ‘N Guard WB OR ² Sure Klean® Gloss ‘N Guard Maintenance Cleaner Enviro Klean® Klean ‘N Release Cleaner (1:10)
“Vals Green – C120 Honed” Quartzite		
“Vals Green – C320 Honed” Quartzite		
“Vals Green – Sandblasted” Quartzite		
“Vals Grey – Brushed” Quartzite		
“Vals Grey – C120 Honed” Quartzite	Sure Klean® 800 Stain Remover OR Sure Klean® Light Duty Restoration Cleaner	
“Vals Grey – C220 Honed” Quartzite	N/A	
“Vals Grey – C320 Honed” Quartzite		
“Vals Grey – Polished” Quartzite		
“Vals Grey – Sandblasted + Brushed” Quartzite		
“Vals Grey – Sandblasted” Quartzite		

NOTE: “1” indicates the most effective product and “2” indicates the second most effective product.

Apply all products in accordance with the manufacturer's recommendation provided on container labels and product data sheets. On-site testing should be conducted to determine the most appropriate product and procedures for a particular project. See product literature for additional application and product information.