



**Glen-Gery
Mid-Atlantic Plant
Shoemakersville, PA
Executive Summary
Project No. 2110-03**

Twenty-one types of clay brick were submitted to AMT Laboratories by PROSOCO, Inc. with a request to determine the most appropriate new construction cleaner. Additionally, adverse effects testing on stain removal/maintenance cleaners suitable for clay brick were evaluated.

The laboratory report (2110-03 PTP Glen-Gery) provides information about the PROSOCO® products tested and descriptions of the test methods. The report includes test results as well as conclusions and recommendations. Recommendations are also provided in the chart below.

Recommendations:

Sample	New Construction Cleaning		Adverse Effects					
	Sure Klean® 600 (1:6) or (1:8)	Sure Klean® Vana Trol® (1:6) or (1:8)	Sure Klean® Ferrous Stain Remover (1:3)	Sure Klean® 800 Stain Remover (1:1)	Sure Klean® White Scum Remover (1:1)	Sure Klean® ReVeal (1:3)	Sure Klean® Restoration Cleaner (1:3)	Enviro Klean® Klean 'N Release Cleaner (1:10)
“Azul” Cored Brick	2☒	1☒	☒	☒	☒	☒	☒	☒
“Castellana” Cored Brick	2☒	1☒	☒	☒	☒	☒	☒	☒
“Romero” Cored Brick	2☒	1☒	☒	☐	☐	☒	☒	☒
“Arno Textured” Solid Brick	1☒	2☒	☒	☒	☒	☒	☒	☒
“Marana Textured” Solid Brick	2☒	1☒	☒	☒	☒	☒	☒	☒
“Piave Textured” Solid Brick	1☒	2☒	☒	☐	☐	☒	☒	☒
“Potenza Textured” Solid Brick	1☒	2☒	☐	☐	☐	☒	☒	☒

NOTE: “1” indicates the recommended first choice and “2” indicates the recommended second choice. These recommendations are based on the Product Data Sheet limitations for certain brick types.

Apply all products in accordance with the manufacturer's recommendation provided on container labels and product data sheets. On-site testing should be conducted to determine the most appropriate product and procedures for a particular project. See product literature for additional application and product information.



**Glen-Gery
Mid-Atlantic Plant
Shoemakersville, PA
Executive Summary
Project No. 2110-03**

Recommendations: (cont.)

Sample	New Construction Cleaning		Adverse Effects					
	Sure Klean® 600 (1:6) or (1:8)	Sure Klean® Vana Trol® (1:6) or (1:8)	Sure Klean® Ferrous Stain Remover (1:3)	Sure Klean® 800 Stain Remover (1:1)	Sure Klean® White Scum Remover (1:1)	Sure Klean® ReVeal (1:3)	Sure Klean® Restoration Cleaner (1:3)	Enviro Klean® Klean 'N Release Cleaner (1:10)
"Arno Raw" Solid Brick	1☒	2☒	☒	☐	☒	☒	☒	☒
"Brenta Raw" Solid Brick	2☒	1☒	☒	☒	☒	☒	☒	☒
"Livenza Raw" Solid Brick	2☒	1☒	☒	☒	☒	☒	☒	☒
"Marana Raw" Solid Brick	2☒	1☒	☒	☒	☒	☒	☒	☒
"Piave Raw" Solid Brick	2☒	1☒	☒	☒	☒	☒	☒	☒
"Potenza Raw" Solid Brick	1☒	2☒	☒	☒	☒	☒	☒	☒
"Feldhaus 100 Classic Cream Smooth" Thin Brick	2☒	1☒	☒	☒	☒	☒	☒	☒
"Feldhaus 401 Classic Red Velour" Thin Brick	1☒	2☒	☒	☐	☐	☒	☒	☒

NOTE: "1" indicates the recommended first choice and "2" indicates the recommended second choice. These recommendations are based on the Product Data Sheet limitations for certain brick types.

Apply all products in accordance with the manufacturer's recommendation provided on container labels and product data sheets. On-site testing should be conducted to determine the most appropriate product and procedures for a particular project. See product literature for additional application and product information.



**Glen-Gery
Mid-Atlantic Plant
Shoemakersville, PA
Executive Summary
Project No. 2110-03**

Recommendations: (cont.)

Sample	New Construction Cleaning		Adverse Effects					
	Sure Klean® 600 (1:6) or (1:8)	Sure Klean® Vana Trol® (1:6) or (1:8)	Sure Klean® Ferrous Stain Remover (1:3)	Sure Klean® 800 Stain Remover (1:1)	Sure Klean® White Scum Remover (1:1)	Sure Klean® ReVeal (1:3)	Sure Klean® Restoration Cleaner (1:3)	Enviro Klean® Klean 'N Release Cleaner (1:10)
"Feldhaus 511 Onyx Smooth" Thin Brick	2☒	1☒	☒	☒	☒	☒	☒	☒
"Feldhaus 567 Coal Brindle Smooth" Thin Brick	2☒	1☒	☒	☐	☒	☒	☒	☒
"Feldhaus 664 Deep Wine Handform" Thin Brick	1☒	2☒	☒	☒	☒	☒	☒	☒
"Feldhaus 764 Gray White Waterstruck" Thin Brick	2☒	1☒	☒	☒	☒	☒	☒	☒
"Feldhaus 777 Onyx Waterstruck" Thin Brick	2☒	1☒	☒	☒	☒	☒	☒	☒
"Feldhaus 800 Classic Gray Smooth" Thin Brick	1☒	2☒	☒	☒	☒	☒	☒	☒

NOTE: "1" indicates the recommended first choice and "2" indicates the recommended second choice. These recommendations are based on the Product Data Sheet limitations for certain brick types.

Apply all products in accordance with the manufacturer's recommendation provided on container labels and product data sheets. On-site testing should be conducted to determine the most appropriate product and procedures for a particular project. See product literature for additional application and product information.