



**Interstate Brick  
West Jordan, UT  
Executive Summary  
Project No. 2209-04**

Three types of clay brick were submitted to AMT Laboratories by PROSOCO, Inc. with a request to determine the most appropriate new construction cleaner. Additionally, water repellent and graffiti resistant products suitable for clay brick were evaluated.

The laboratory report (2209-04 PTP Interstate Brick) provides information about the PROSOCO® products tested and descriptions of the test methods. The report includes test results as well as photographs, conclusions, and recommendations. Recommendations are also provided in the chart below.

**Recommendations:**

Sample	New Construction Cleaning	Water Repellency	Graffiti Repellency	Graffiti Removal
"Black Ice" Coated Brick	<sup>1</sup> Sure Klean® Vana Trol® (1:6) or (1:8) OR <sup>2</sup> Sure Klean® 600 (1:6) or (1:8)	Sure Klean® Weather Seal Blok-Guard® & Graffiti Control 9 OR Sure Klean® Weather Seal Blok-Guard® & Graffiti Control VOC 15 OR Sure Klean® Weather Seal Blok-Guard® & Graffiti Control WB 15 OR Sure Klean® Weather Seal Siloxane PD OR Sure Klean® Weather Seal Siloxane WB Concentrate (1:9) or (1:14)	Sure Klean® Weather Seal Blok-Guard® & Graffiti Control 9 OR Sure Klean® Weather Seal Blok-Guard® & Graffiti Control VOC 15 OR Sure Klean® Weather Seal Blok-Guard® & Graffiti Control WB 15	<u><b>Graffiti Removers</b></u> <sup>1</sup> Sure Klean® Graffiti Remover OR <sup>2</sup> Enviro Klean® SafStrip®
"Black Opal" Coated Brick			Sure Klean® Weather Seal Blok-Guard® & Graffiti Control 9 OR Sure Klean® Weather Seal Blok-Guard® & Graffiti Control WB 15	
"Obsidian" Coated Brick			Sure Klean® Weather Seal Blok-Guard® & Graffiti Control 9 OR Sure Klean® Weather Seal Blok-Guard® & Graffiti Control WB 15	

NOTE: "1" indicates the recommended first choice and "2" indicates the recommended second choice. These recommendations are based on the Product Data Sheet limitations for certain brick types.

Apply all products in accordance with the manufacturer's recommendation provided on container labels and product data sheets. On-site testing should be conducted to determine the most appropriate product and procedures for a particular project. See product literature for additional application and product information.