



**Northfield Block  
an Oldcastle Company  
Morris, IL  
Executive Summary  
Project No. 2301-03**

Fourteen types of full bed depth concrete masonry stone veneers were submitted to AMT Laboratories by PROSOCO, Inc. with a request to determine the most appropriate new construction cleaner. Additionally, color and sheen enhancement and graffiti resistant products suitable for the submitted samples were evaluated.

The laboratory report (2301-03 PTP Northfield Block Company an Oldcastle Company) provides information about the PROSOCO® products tested and descriptions of the test methods. The report includes test results as well as conclusions and recommendations. Recommendations are also provided in the chart below.

**Recommendations:**

Sample	New Construction Cleaning	Color and Sheen Enhancement	Graffiti Resistance
“Alabaster” Ground Face CORDOVA Stone®	Sure Klean® Light Duty Concrete Cleaner (1:3) or (1:6) OR Sure Klean® Vana Trol® (1:6) or (1:8) OR Enviro Klean® Safety Klean (1:2) or (1:3)	Please refer to pages 21-36 of the report for individual recommendations based on the desired result.	<b><u>Graffiti Repellents</u></b> <sup>1</sup> Sure Klean® Weather Seal Blok-Guard® & Graffiti Control WB 15 OR <sup>2</sup> Sure Klean® Weather Seal Blok-Guard® & Graffiti Control 9 OR <sup>2</sup> Sure Klean® Weather Seal Sacrificial Coating SC-1
“Buff” Ground Face CORDOVA Stone®			
“Graphite” Ground Face CORDOVA Stone®			
“Limestone” Ground Face CORDOVA Stone®			
“Midnight” Ground Face CORDOVA Stone®			
			<b><u>Graffiti Removers</u></b> <sup>1</sup> Sure Klean® Graffiti Remover OR <sup>2</sup> Enviro Klean® SafStrip® 8
			<b><u>Graffiti Repellents</u></b> Sure Klean® Weather Seal Sacrificial Coating SC-1  <b><u>Graffiti Removers</u></b> Hot Water Only

NOTE: “1” indicates the recommended first choice and “2” indicates the recommended second choice.

Please refer to the Product Data Sheet or visit [www.prosoco.com/voccompliance](http://www.prosoco.com/voccompliance) to confirm VOC compliance with individual district or state regulations.

Apply all products in accordance with the manufacturer's recommendation provided on container labels and product data sheets. On-site testing should be conducted to determine the most appropriate product and procedures for a particular project. See product literature for additional application and product information.



**Northfield Block  
an Oldcastle Company  
Morris, IL  
Executive Summary  
Project No. 2301-03**

**Recommendations: (cont.)**

Sample	New Construction Cleaning	Color and Sheen Enhancement	Graffiti Resistance
“Alabaster” Texture Face CORDOVA Stone®	Sure Klean® Light Duty Concrete Cleaner (1:3) or (1:6) OR Sure Klean® Vana Trol® (1:6) or (1:8) OR Enviro Klean® Safety Klean (1:2) or (1:3)	Please refer to pages 21-36 of the report for individual recommendations based on the desired result.	<p style="text-align: center;"><b><u>Graffiti Repellents</u></b></p> <sup>1</sup> Sure Klean® Weather Seal Blok-Guard® & Graffiti Control WB 15 OR <sup>2</sup> Sure Klean® Weather Seal Blok-Guard® & Graffiti Control 9 OR <sup>2</sup> Sure Klean® Weather Seal Sacrificial Coating SC-1
“Buff” Texture Face CORDOVA Stone®			
“Graphite” Texture Face CORDOVA Stone®			
“Limestone” Texture Face CORDOVA Stone®			
“Midnight” Texture Face CORDOVA Stone®			
“Congress Tan” Smooth Face Franklin Stone®	<sup>1</sup> Sure Klean® Light Duty Concrete Cleaner (1:3) or (1:6) OR <sup>1</sup> Sure Klean® Vana Trol® (1:6) or (1:8)		
“Liberty Gray” Smooth Face Franklin Stone®	<sup>2</sup> Enviro Klean® Safety Klean (1:2) or (1:3)		
“Monument White” Smooth Face Franklin Stone®	<sup>1</sup> Sure Klean® Light Duty Concrete Cleaner (1:3) or (1:6) OR <sup>2</sup> Sure Klean® Vana Trol® (1:6) or (1:8)		
“Senate Sage” Smooth Face Franklin Stone®	<sup>2</sup> Enviro Klean® Safety Klean (1:2) or (1:3)		

NOTE: “1” indicates the recommended first choice and “2” indicates the recommended second choice.

Please refer to the Product Data Sheet or visit [www.prosoco.com/voccompliance](http://www.prosoco.com/voccompliance) to confirm VOC compliance with individual district or state regulations.

Apply all products in accordance with the manufacturer's recommendation provided on container labels and product data sheets. On-site testing should be conducted to determine the most appropriate product and procedures for a particular project. See product literature for additional application and product information.