

Silverdale Quality Stone Arkansas City, KS

Executive Summary

Project No. 2302-03

One type of natural stone was submitted to AMT Laboratories by PROSOCO, Inc. with a request to determine the most appropriate new construction cleaner. Additionally, water repellent and graffiti resistant products suitable for the natural stone were evaluated.

The laboratory report (2302-03 PTP Silverdale Quality Stone) provides information about the PROSOCO® products tested and descriptions of the test methods. The report includes test results as well as conclusions and recommendations. Recommendations are also provided in the chart below.

Recommendations:

Sample	New Construction Cleaning	Water Repellency	Graffiti Resistance
"Silverdale" Smooth Limestone	¹ Sure Klean® Vana Trol® (1:6) or (1:8) OR ² Enviro Klean® Safety Klean (1:2) or (1:3)	Sure Klean® Weather Seal Blok-Guard & Graffiti Control 15 OR Sure Klean® Weather Seal Natural Stone Treatment WB followed by Sure Klean® Weather Seal Blok-Guard & Graffiti Control WB 15 OR Sure Klean® Weather Seal Natural Stone Treatment OR Sure Klean® Weather Seal Natural Stone Treatment OR Treatment WB	Graffiti Repellents 1Sure Klean® Weather Seal Sacrificial Coating SC-1 OR 2Sure Klean® Weather Seal Natural Stone Treatment WB followed by Sure Klean® Weather Seal Blok-Guard & Graffiti Control WB 15 Graffiti Removers Enviro Klean® SafStrip® 8 OR Sure Klean® Graffiti Remover

NOTE: "1" indicates the most effective product and "2" indicates the second most effective product.

Please refer to the Product Data Sheet or visit www.prosoco.com/voccompliance to confirm VOC compliance with individual district or state regulations.

Apply all products in accordance with the manufacturer's recommendation provided on container labels and product data sheets. On-site testing should be conducted to determine the most appropriate product and procedures for a particular project. See product literature for additional application and product information.