



Bassco Cast Stone
Elkmont, AL
Executive Summary
 Project No. 2304-02

Five types of cast stone (dry cast and wet cast) were submitted to AMT Laboratories by PROSOCO, Inc. with a request to determine the most appropriate new construction cleaner. Additionally, color and sheen enhancement, water repellent, graffiti resistant, and stain resistant products suitable for cast stone were evaluated.

The laboratory report (2304-02 PTP Bassco Cast Stone) provides information about the PROSOCO® products tested and descriptions of the test methods. The report includes test results as well as conclusions and recommendations. Recommendations are also provided in the chart below.

Recommendations:

Sample	New Construction Cleaning	Color and Sheen Enhancement	Water Repellency	Graffiti Resistance	Stain Resistance
“Brushed Buff” Cast Stone – Dry Cast	Sure Klean® Light Duty Concrete Cleaner (1:2) or (1:3) OR Sure Klean® Vana Trol® (1:6) or (1:8)	Please refer to pages 12-19 of the report for individual recommendations based on the desired result.	Sure Klean® Weather Seal Siloxane PD OR Sure Klean® Weather Seal Blok-Guard® & Graffiti Control 9 OR Sure Klean® Weather Seal Blok-Guard® & Graffiti Control WB 15	<u>Graffiti Repellents</u> ¹ Sure Klean® Weather Seal Blok-Guard® & Graffiti Control WB 15 OR ² Sure Klean® Weather Seal Blok-Guard® & Graffiti Control 9 <u>Graffiti Removers</u> ¹ Sure Klean® Graffiti Remover OR ² Enviro Klean® SafStrip® 8	<u>Stain Repellents</u> ¹ Sure Klean® Weather Seal Satin Guard WB OR ² Sure Klean® Weather Seal Gloss ‘N Guard
“Pearly White” Cast Stone – Dry Cast					<u>Maintenance Cleaner</u> Enviro Klean® Klean ‘N Release Cleaner
“Brushed Buff” Cast Stone – Wet Cast					<u>Stain Repellents</u> Sure Klean® Weather Seal Satin Guard WB OR Sure Klean® Weather Seal Gloss ‘N Guard
“Natural Buff” Cast Stone – Wet Cast					<u>Maintenance Cleaner</u> Enviro Klean® Klean ‘N Release Cleaner
“Pearly White” Cast Stone – Wet Cast					

NOTE: “1” indicates the most effective product and “2” indicates the second most effective product.

Apply all products in accordance with the manufacturer's recommendation provided on container labels and product data sheets. On-site testing should be conducted to determine the most appropriate product and procedures for a particular project. See product literature for additional application and product information.