



ABC Block & Brick
Little Rock, AR
Executive Summary
 Project No. 2304-03

Five types of concrete brick were submitted to AMT Laboratories by PROSOCO, Inc. with a request to determine the most appropriate new construction cleaner. Additionally, water repellent and graffiti resistant products suitable for the submitted samples were evaluated.

The laboratory report (2304-03 PTP ABC Block & Brick) provides information about the PROSOCO® products tested and descriptions of the test methods. The report includes test results as well as conclusions and recommendations. Recommendations are also provided in the chart below.

Recommendations:

Sample	New Construction Cleaning	Water Repellency	Graffiti Resistance
“Black Diamond” Concrete Brick	Sure Klean® Custom Masonry Cleaner (1:6) OR Sure Klean® Vana Trol® (1:8)		
“Oakwood” Concrete Brick		Sure Klean® Weather Seal Siloxane WB Concentrate (1:9) OR	Graffiti Repellents ¹ Sure Klean® Weather Seal Blok-Guard® & Graffiti Control WB 15 OR
“Silverado” Concrete Brick	Sure Klean® Custom Masonry Cleaner (1:4) or (1:6) OR Sure Klean® Vana Trol® (1:6) or (1:8)	Sure Klean® Weather Seal Blok-Guard® & Graffiti Control 9 OR	² Sure Klean® Weather Seal Blok-Guard® & Graffiti Control 9
“Stone Mountain” Concrete Brick	OR Sure Klean® 600 (1:6) or (1:8)	Sure Klean® Weather Seal Blok-Guard® & Graffiti Control WB 15	Graffiti Removers ¹ Sure Klean® Graffiti Remover OR ² Enviro Klean® SafStrip® 8
“Winter Ice” Concrete Brick			

NOTE: “1” indicates the recommended first choice and “2” indicates the recommended second choice.

Please refer to the Product Data Sheet or visit www.prosoco.com/voccompliance to confirm VOC compliance with individual district or state regulations.

Apply all products in accordance with the manufacturer's recommendation provided on container labels and product data sheets. On-site testing should be conducted to determine the most appropriate product and procedures for a particular project. See product literature for additional application and product information.