



**ABC Block & Brick**  
**Little Rock, AR**  
**Executive Summary**  
 Project No. 2304-03

Five types of concrete brick were submitted to AMT Laboratories by PROSOCO, Inc. with a request to determine the most appropriate new construction cleaner. Additionally, water repellent and graffiti resistant products suitable for the submitted samples were evaluated.

The laboratory report (2304-03 PTP ABC Block & Brick) provides information about the PROSOCO® products tested and descriptions of the test methods. The report includes test results as well as conclusions and recommendations. Recommendations are also provided in the chart below.

**Recommendations:**

<b>Sample</b>	<b>New Construction Cleaning</b>	<b>Water Repellency</b>	<b>Graffiti Resistance</b>
“Black Diamond” Concrete Brick	Sure Klean® Custom Masonry Cleaner (1:6) OR Sure Klean® Vana Trol® (1:8)		
“Oakwood” Concrete Brick	Sure Klean® Custom Masonry Cleaner (1:4) or (1:6) OR Sure Klean® Vana Trol® (1:6) or (1:8) OR Sure Klean® 600 (1:6) or (1:8)	Sure Klean® Weather Seal Siloxane WB Concentrate (1:9) OR	<b><u>Graffiti Repellents</u></b> <sup>1</sup> Sure Klean® Weather Seal Blok-Guard® & Graffiti Control WB 15 OR
“Silverado” Concrete Brick		Sure Klean® Weather Seal Siloxane PD OR	<sup>2</sup> Sure Klean® Weather Seal Blok-Guard® & Graffiti Control 9
“Stone Mountain” Concrete Brick		Sure Klean® Weather Seal Blok-Guard® & Graffiti Control 9 OR	<b><u>Graffiti Removers</u></b> <sup>1</sup> Sure Klean® Graffiti Remover OR
“Winter Ice” Concrete Brick		Sure Klean® Weather Seal Blok-Guard® & Graffiti Control WB 15	<sup>2</sup> Enviro Klean® SafStrip® 8

NOTE: “1” indicates the recommended first choice and “2” indicates the recommended second choice.

Please refer to the Product Data Sheet or visit [www.prosoco.com/voccompliance](http://www.prosoco.com/voccompliance) to confirm VOC compliance with individual district or state regulations.

Apply all products in accordance with the manufacturer's recommendation provided on container labels and product data sheets. On-site testing should be conducted to determine the most appropriate product and procedures for a particular project. See product literature for additional application and product information.