



**Reading Rock  
Cincinnati, OH  
Executive Summary  
Project No. 2306-02**

Six types of RockCast masonry veneer precast concrete were submitted to AMT Laboratories by PROSOCO, Inc. with a request to determine the most appropriate new construction cleaner and efflorescence removal products.

The laboratory report (2306-02 PTP Reading Rock) provides information about the PROSOCO® products tested and descriptions of the test methods. The report includes test results as well as conclusions and recommendations. Recommendations are also provided in the chart below.

**Recommendations:**

Sample	New Construction Cleaning	Efflorescence Removal
"Shadow" RockCast Smooth Masonry Veneer	Sure Klean® Light Duty Concrete Cleaner <sup>2</sup> (1:2) or <sup>2</sup> (1:3) or <sup>1</sup> (1:6) OR Sure Klean® Vana Trol® <sup>2</sup> (1:6) or <sup>2</sup> (1:8) or <sup>2</sup> (1:10)	Sure Klean® Light Duty Concrete Cleaner (1:2) OR Sure Klean® Vana Trol® (1:6)
"Caliza" RockCast Smooth Masonry Veneer		
"Smokehouse" RockCast Smooth Masonry Veneer	Sure Klean® Light Duty Concrete Cleaner (1:2) or (1:3) or (1:6) OR Sure Klean® Custom Masonry Cleaner (1:4) or (1:6) OR Sure Klean® Vana Trol® (1:6) or (1:8) or (1:10)	N/A
"Buff" RockCast Split Masonry Veneer		
"Buff" RockCast Smooth Masonry Veneer		
"Loudon County" RockCast Smooth Masonry Veneer	Sure Klean® Light Duty Concrete Cleaner <sup>2</sup> (1:2) or <sup>1</sup> (1:3) or <sup>1</sup> (1:6)	

NOTE: "1" indicates the most effective product and "2" indicates the second most effective product.

Apply all products in accordance with the manufacturer's recommendation provided on container labels and product data sheets. On-site testing should be conducted to determine the most appropriate product and procedures for a particular project. See product literature for additional application and product information.