



**Acme Brick Company**  
**Fort Worth, TX**  
**Executive Summary**  
 Project No. 2308-04

Three types of Agrob Buchtal KeraTwin Panels were submitted to AMT Laboratories by PROSOCO, Inc. with a request to determine the most appropriate new construction cleaner. Additionally, color and sheen enhancement, water repellent, graffiti resistant, and stain resistant products suitable for the “396” terracotta panel were evaluated.

The laboratory report (2308-04 PTP Acme Brick Company) provides information about the PROSOCO® products tested and descriptions of the test methods. The report includes test results as well as conclusions and recommendations. Recommendations are also provided in the chart below.

**Recommendations:**

Sample	New Construction Cleaning	Color and Sheen Enhancement	Water Repellency	Graffiti Resistance	Stain Resistance
“396” Terracotta Panel	Sure Klean® Vana Trol® (1:6) or (1:8) OR Enviro Klean® Safety Klean (1:2) or (1:3)	Please refer to pages 12-14 of the report for individual recommendations based on the desired result.	PROSOCO Saltguard® VOC OR Sure Klean® Weather Seal Siloxane PD OR Sure Klean® Weather Seal Siloxane WB Concentrate (1:14)	<u><b>Graffiti Repellents</b></u> Sure Klean® Weather Seal Sacrificial Coating SC-1  <u><b>Graffiti Removers</b></u> Hot Water Only	<u><b>Stain Repellents</b></u> <sup>1</sup> Sure Klean® Weather Seal Satin Guard WB OR <sup>2</sup> Sure Klean® Weather Seal Gloss ‘N Guard  <u><b>Maintenance Cleaner</b></u> Enviro Klean® Klean ‘N Release Cleaner
“409” Terracotta Panel			Not applicable due to the titanium dioxide coating.	<u><b>Graffiti Repellents</b></u> Not applicable due to the titanium dioxide coating.	Not applicable due to the titanium dioxide coating.
“410” Terracotta Panel			<u><b>Graffiti Removers</b></u> Enviro Klean® SafStrip® OR Sure Klean® Graffiti Remover		

NOTE: “1” indicates the most effective product and “2” indicates the second most effective product.

Please refer to the Product Data Sheet or visit [www.prosoco.com/voccompliance](http://www.prosoco.com/voccompliance) to confirm VOC compliance with individual district or state regulations.

Apply all products in accordance with the manufacturer's recommendation provided on container labels and product data sheets. On-site testing should be conducted to determine the most appropriate product and procedures for a particular project. See product literature for additional application and product information.