



Mutual Materials – Split Face CMU

Bellevue, WA

Executive Summary

Project No. 2309-02

Thirteen types of split face CMUs were submitted to AMT Laboratories by PROSOCO, Inc. with a request to determine the most appropriate new construction cleaner. Additionally, color and sheen enhancement, water repellent, and graffiti resistant products suitable for split face CMUs were evaluated.

The laboratory report (2309-02 PTP Mutual Materials – Split Face CMU) provides information about the PROSOCO® products tested and descriptions of the test methods. The report includes test results as well as conclusions and recommendations. Recommendations are also provided in the chart below.

Recommendations:

Sample	New Construction Cleaning	Color and Sheen Enhancement	Water Repellency	Graffiti Resistance
“Natural” Split Face CMU	Sure Klean® Light Duty Concrete Cleaner ² (1:2) or ¹ (1:3) OR Sure Klean® Vana Trol® ² (1:6) or ¹ (1:8) OR Sure Klean® Custom Masonry Cleaner ² (1:4) or ¹ (1:6)	Please refer to pages 19-34 of the report for individual recommendations based on the desired result.	Sure Klean® Weather Seal Blok-Guard® & Graffiti Control WB 6 OR Sure Klean® Weather Seal Blok-Guard® & Graffiti Control WB 15 OR Sure Klean® Weather Seal Blok-Guard® & Graffiti Control 15 OR PROSOCO® Saltguard® OR Sure Klean® Weather Seal Siloxane WB Concentrate	<p style="text-align: center;"><u>Graffiti Repellents</u></p> ¹ Sure Klean® Weather Seal Blok-Guard® & Graffiti Control WB 15 OR ² Sure Klean® Weather Seal Blok-Guard® & Graffiti Control 15 OR ³ Sure Klean® Weather Seal Blok-Guard® & Graffiti Control WB 6 <p style="text-align: center;"><u>Graffiti Removers</u></p> Enviro Klean® SafStrip® 8 OR Sure Klean® Graffiti Remover
“Charcoal” Split Face CMU				
“Rose Brown” Split Face CMU				
“Khaki” Split Face CMU				
“Castle White” Split Face CMU				
“Sandstone” Split Face CMU				
“Mesa Tan” Split Face CMU				
“Burgundy Red” Split Face CMU				
“Mountain Brown” Split Face CMU				
“Driftwood” Split Face CMU				

NOTE: “1” indicates the most effective product, “2” indicates the second most effective product, and “3” indicates the third most effective product.

Apply all products in accordance with the manufacturer's recommendation provided on container labels and product data sheets. On-site testing should be conducted to determine the most appropriate product and procedures for a particular project. See product literature for additional application and product information.



Mutual Materials – Split Face CMU

Bellevue, WA

Executive Summary

Project No. 2309-02

Recommendations: (cont.)

Sample	New Construction Cleaning	Color and Sheen Enhancement	Water Repellency	Graffiti Resistance
"Cocoa" Split Face CMU	Sure Klean® Light Duty Concrete Cleaner ² (1:2) or ¹ (1:3) OR Sure Klean® Vana Trol® ² (1:6) or ² (1:8) OR Sure Klean® Custom Masonry Cleaner ² (1:4) or ¹ (1:6)	Please refer to pages 19-34 of the report for individual recommendations based on the desired result.	Sure Klean® Weather Seal Blok-Guard® & Graffiti Control WB 6 OR Sure Klean® Weather Seal Blok-Guard® & Graffiti Control WB 15 OR Sure Klean® Weather Seal Blok-Guard® & Graffiti Control 15 OR PROSOCO® Saltguard® OR Sure Klean® Weather Seal Siloxane WB Concentrate	<u>Graffiti Repellents</u> ¹ Sure Klean® Weather Seal Blok-Guard® & Graffiti Control WB 15 OR ² Sure Klean® Weather Seal Blok-Guard® & Graffiti Control 15 OR ³ Sure Klean® Weather Seal Blok-Guard® & Graffiti Control WB 6 <u>Graffiti Removers</u> Enviro Klean® SafStrip® 8 OR Sure Klean® Graffiti Remover
"Sable" Split Face CMU	Sure Klean® Light Duty Concrete Cleaner ¹ (1:2) or ¹ (1:3) OR Sure Klean® Vana Trol® ² (1:6) or ² (1:8) OR Sure Klean® Custom Masonry Cleaner ² (1:4) or ¹ (1:6)			
"Onyx" Split Face CMU	Sure Klean® Light Duty Concrete Cleaner ² (1:2) or ¹ (1:3) OR Sure Klean® Vana Trol® ² (1:8) OR Sure Klean® Custom Masonry Cleaner ² (1:6)			

NOTE: "1" indicates the most effective product, "2" indicates the second most effective product, and "3" indicates the third most effective product.

Apply all products in accordance with the manufacturer's recommendation provided on container labels and product data sheets. On-site testing should be conducted to determine the most appropriate product and procedures for a particular project. See product literature for additional application and product information.