



**Custom Cast Stone
Westfield, IN
Executive Summary
Project No. 2401-05**

Thirteen types of cast stone were submitted to AMT Laboratories by PROSOCO, Inc. with a request to determine the most appropriate new construction cleaner. Additionally, water repellent and graffiti resistant products suitable for cast stone were evaluated.

The laboratory report (2401-05 PTP Custom Cast Stone) provides information about the PROSOCO® products tested and descriptions of the test methods. The report includes test results as well as conclusions and recommendations. Recommendations are also provided in the chart below.

Recommendations:

Sample	New Construction Cleaning	Water Repellency	Graffiti Resistance
“Arbury Blend” Cast Stone	¹ Sure Klean® Vana Trol® (1:6) or (1:8) OR ² Sure Klean® Light Duty Concrete Cleaner (1:2) or (1:3) OR ² Enviro Klean® Safety Klean (1:2) or (1:3)	Sure Klean® Weather Seal Blok-Guard® & Graffiti Control 9 OR Sure Klean® Weather Seal Blok-Guard® & Graffiti Control WB 6 OR Sure Klean® Weather Seal Blok-Guard® & Graffiti Control WB 15 OR Sure Klean® Weather Seal Siloxane PD OR Sure Klean® Weather Seal Weather Seal GP	<p align="center"><u>Graffiti Repellents</u></p> ¹ Sure Klean® Weather Seal Blok-Guard® & Graffiti Control WB 15 OR ² Sure Klean® Weather Seal Blok-Guard® & Graffiti Control 9 OR ³ Sure Klean® Weather Seal Blok-Guard® & Graffiti Control WB 6 <p align="center"><u>Graffiti Removers</u></p> Enviro Klean® SafStrip® 8 OR Sure Klean® Graffiti Remover
“Bark” Cast Stone			
“Ginger” Cast Stone			
“Natural” Cast Stone			
“Natural White” Cast Stone			
“Olive Buff” Cast Stone			
“Slate” Cast Stone			
“Super Black” Cast Stone			

NOTE: “1” indicates the most effective product, “2” indicates the second most effective product, and “3” indicates the third most effective product.

Apply all products in accordance with the manufacturer’s recommendation provided on container labels and product data sheets. On-site testing should be conducted to determine the most appropriate product and procedures for a particular project. See product literature for additional application and product information.



**Custom Cast Stone
Westfield, IN
Executive Summary
Project No. 2401-05**

Recommendations: (cont.)

Sample	New Construction Cleaning	Water Repellency	Graffiti Resistance
"Brick Red" Cast Stone	¹ Sure Klean® Vana Trol® (1:6) or (1:8) OR ² Enviro Klean® Safety Klean (1:2) or (1:3) OR ³ Sure Klean® Light Duty Concrete Cleaner (1:2) or (1:3)	Sure Klean® Weather Seal Blok-Guard® & Graffiti Control 9 OR Sure Klean® Weather Seal Blok-Guard® & Graffiti Control WB 6 OR Sure Klean® Weather Seal Blok-Guard® & Graffiti Control WB 15 OR Sure Klean® Weather Seal Siloxane PD OR Sure Klean® Weather Seal Weather Seal GP	<p align="center"><u>Graffiti Repellents</u></p> ¹ Sure Klean® Weather Seal Blok-Guard® & Graffiti Control WB 15 OR ² Sure Klean® Weather Seal Blok-Guard® & Graffiti Control 9 OR ³ Sure Klean® Weather Seal Blok-Guard® & Graffiti Control WB 6 <p align="center"><u>Graffiti Removers</u></p> Enviro Klean® SafStrip® 8 OR Sure Klean® Graffiti Remover
"Cotton" Cast Stone			
"Dark Buff" Cast Stone			
"Light Buff" Cast Stone			
"Sandstone" Cast Stone			

NOTE: "1" indicates the most effective product, "2" indicates the second most effective product, and "3" indicates the third most effective product.

Apply all products in accordance with the manufacturer's recommendation provided on container labels and product data sheets. On-site testing should be conducted to determine the most appropriate product and procedures for a particular project. See product literature for additional application and product information.