



**ProVia Executive Summary**  
**Sugarcreek, OH**  
**Executive Summary**  
 Project No. 2401-06

Thirty-nine types of manufactured stone veneers were submitted to AMT Laboratories by PROSOCO, Inc. with a request to determine the most appropriate new construction cleaner. Additionally, water repellent products suitable for manufactured stone veneers were evaluated.

The laboratory report (2401-06 PTP ProVia) provides information about the PROSOCO® products tested and descriptions of the test methods. The report includes test results as well as conclusions and recommendations. Recommendations are also provided in the chart below.

**Recommendations:**

Sample	New Construction Cleaning	Maintenance Cleaning	Water Repellency
"Silverlake" Chisel Cut	Sure Klean® Light Duty Concrete Cleaner (1:3) or (1:6) OR Sure Klean® Vana Trol® (1:8) or (1:10)	Enviro Klean® 2010 All Surface Cleaner® (1:10)	Sure Klean® Weather Seal Siloxane PD OR Sure Klean® Weather Seal Siloxane WB Concentrate (1:9)
"Wellington" Chisel Cut			
"Chestnut" Dry Stack			
"Ottawa" Dry Stack			
"Whisperwood" Dry Stack			
"Beech" Edge Cut			
"Polar" Edge Cut			
"Tundra" Edge Cut			
"Mystic" LedgeStone			
"Osage" LedgeStone			
"Ohio Vintage" Limestone			
"Vail" Limestone			

Apply all products in accordance with the manufacturer's recommendation provided on container labels and product data sheets. On-site testing should be conducted to determine the most appropriate product and procedures for a particular project. See product literature for additional application and product information.



**ProVia Executive Summary**  
**Sugarcreek, OH**  
**Executive Summary**  
 Project No. 2401-06

**Recommendations: (cont.)**

Sample	New Construction Cleaning	Maintenance Cleaning	Water Repellency
"Alta" Natural Cut	Sure Klean® Light Duty Concrete Cleaner (1:3) or (1:6) OR Sure Klean® Vana Trol® (1:8) or (1:10)	Enviro Klean® 2010 All Surface Cleaner® (1:10)	Sure Klean® Weather Seal Siloxane PD OR Sure Klean® Weather Seal Siloxane WB Concentrate (1:9)
"Adobe Sands" Precisionfit			
"Arctic" Precisionfit			
"Denali" Ridge Cut			
"Rainer" Terra Cut			
"Summit" Terra Cut			
"Rushmore" LedgeStone	Sure Klean® Light Duty Concrete Cleaner (1:3) or (1:6)		
"Fernwood" Natural Cut	Sure Klean® Light Duty Concrete Cleaner (1:6) OR Sure Klean® Vana Trol® (1:10)		
"Mountain" River Rock	Sure Klean® Light Duty Concrete Cleaner (1:6)		
"Slate" Terra Cut			
"Brindle" Chisel Cut	None		
"Olympus" Chisel Cut			
"Catawba" Dry Stack			
"Obsidian" Edge Cut			

Apply all products in accordance with the manufacturer's recommendation provided on container labels and product data sheets. On-site testing should be conducted to determine the most appropriate product and procedures for a particular project. See product literature for additional application and product information.



**ProVia Executive Summary**  
**Sugarcreek, OH**  
**Executive Summary**  
 Project No. 2401-06

**Recommendations: (cont.)**

Sample	New Construction Cleaning	Maintenance Cleaning	Water Repellency
"Pennsylvania" Fieldstone	None	Enviro Klean® 2010 All Surface Cleaner® (1:10)	Sure Klean® Weather Seal Siloxane PD OR Sure Klean® Weather Seal Siloxane WB Concentrate (1:9)
"Shenandoah" Fieldstone			
"Strathmore" Fieldstone			
"Oxford" Ledge stone			
"Allegheny" Limestone			
"Blue Ridge" Limestone			
"Ashworth" Natural Cut			
"Driftwood" Precisionfit			
"Onyx" Precisionfit			
"Castle Rock" Ridge Cut			
"Yosemite" Ridge Cut			
"Michigan" River Rock			
"Russet" Terra Cut			

Apply all products in accordance with the manufacturer's recommendation provided on container labels and product data sheets. On-site testing should be conducted to determine the most appropriate product and procedures for a particular project. See product literature for additional application and product information.