



**Castohn
Tacoma, WA
Executive Summary
Project No. 2404-01**

Eleven types of concrete pavers were submitted to AMT Laboratories by PROSOCO, Inc. with a request to determine the most appropriate new construction cleaner. Additionally, stain removal, color and sheen enhancement, water repellent, and stain resistant products suitable for concrete pavers were evaluated.

The laboratory report (2404-01 PTP Castohn) provides information about the PROSOCO® products tested and descriptions of the test methods. The report includes test results as well as conclusions and recommendations. Recommendations are also provided in the chart below.

Recommendations:

Sample	New Construction Cleaning	Color and Sheen Enhancement	Water Repellency	Stain Resistance
“Charcoal” Mountain Slate	¹ Sure Klean® Light Duty Concrete Cleaner (1:2) or (1:3) OR	Please refer to pages 18-26 of the report for individual recommendations based on the desired result.	PROSOCO® Saltguard® WB OR PROSOCO® SL100 Water Repellent OR Sure Klean® Weather Seal Color Enhancer WB	Stain Repellents Sure Klean® Weather Seal Satin Guard WB Maintenance Cleaner Enviro Klean® Klean ‘N Release Cleaner
“Natural Gray” Mountain Slate	² Sure Klean® Heavy Duty Concrete Cleaner (1:4) or (1:6) OR ² Sure Klean® Vana Trol® (1:6) or (1:8) OR ² Enviro Klean® Safety Klean (1:2) or (1:3)			
“Charcoal” Olympic Paver	Sure Klean® Light Duty Concrete Cleaner (1:2) or (1:3) OR Sure Klean® Heavy Duty Concrete Cleaner (1:4) or (1:6) OR Sure Klean® Vana Trol® (1:6) or (1:8) OR Enviro Klean® Safety Klean (1:2) or (1:3)			
“Natural Gray” Olympic Paver				
“Charcoal” Smooth Alpine	¹ Sure Klean® Light Duty Concrete Cleaner (1:2) or (1:3) OR ³ Sure Klean® Heavy Duty Concrete Cleaner (1:4) or (1:6) OR ² Sure Klean® Vana Trol® (1:6) or (1:8) OR ² Enviro Klean® Safety Klean (1:2) or (1:3)			
“Natural Gray” Smooth Alpine				

NOTE: “1” indicates the recommended first choice, “2” indicates the recommended second choice, and “3” indicates the recommended third choice.

Apply all products in accordance with the manufacturer's recommendation provided on container labels and product data sheets. On-site testing should be conducted to determine the most appropriate product and procedures for a particular project. See product literature for additional application and product information.

Please refer to the Product Data Sheet or visit www.prosoco.com/voccompliance to confirm VOC compliance with individual district or state regulations.



**Castohn
Tacoma, WA
Executive Summary
Project No. 2404-01**

Recommendations: (cont.)

Sample	Stain Removal
"Bluestone" Dimensional Flagstone	Sure Klean® Light Duty Concrete Cleaner (1:2) OR Enviro Klean® Safety Klean (1:2)
"Pacific Mist" Linear Slate	
"Silver Legacy" Linear Slate	
"Western Buff" Linear Slate	
"Western Buff" New Mission	

Apply all products in accordance with the manufacturer's recommendation provided on container labels and product data sheets. On-site testing should be conducted to determine the most appropriate product and procedures for a particular project. See product literature for additional application and product information.

Please refer to the Product Data Sheet or visit www.prosoco.com/voccompliance to confirm VOC compliance with individual district or state regulations.