



Arriscraft
Fort Valley, GA
Executive Summary
 Project No. 2502-04

Thirteen types of calcium silicate masonry units (CSMU) were submitted to AMT Laboratories by PROSOCO, Inc. with a request to determine the most appropriate new construction cleaner. Additionally, water repellent products suitable for CSMU were evaluated.

The laboratory report (2502-04 PTP Arriscraft) provides information about the PROSOCO® products tested and descriptions of the test methods. The report includes test results as well as conclusions and recommendations. Recommendations are also provided in the chart below.

Recommendations:

Sample	New Construction Cleaning	Water Repellency
Rocked "Limestone" CSMU	¹ Sure Klean® Vana Trol® (1:6) or (1:8) OR ² Sure Klean® Light Duty Concrete Cleaner (1:2) or (1:3)	Sure Klean® Weather Seal Siloxane WB Concentrate (1:14) OR Sure Klean® Weather Seal Natural Stone Treatment WB
Satin "Basalt" CSMU		
Satin "Champagne" CSMU		
Satin "Limestone" CSMU		
Satin "Montecito" CSMU		
Satin "Mountain Ridge" CSMU		
Satin "Sunset" CSMU		
Satin "Tan" CSMU		
Smooth "Café" CSMU		
Smooth "Ginger" CSMU		
Smooth "Magnolia" CSMU		
Smooth "Oak Ridge" CSMU		
Smooth "Red Rock" CSMU		

NOTE: "1" indicates the recommended first choice and "2" indicates the recommended second choice.

Apply all products in accordance with the manufacturer's recommendation provided on container labels and product data sheets. On-site testing should be conducted to determine the most appropriate product and procedures for a particular project. See product literature for additional application and product information.